

Additional Agenda for discussions in the 20th meeting of the STU
Coordination Committee to be held on 29.6.2012 at 3.00 P.M under the
chairmanship of Pr. Secretary (MPP & Power)

1. Grant of connectivity to Shaung HEP (3 MW):-

- Developer of Shaung HEP has applied for connectivity to HPPTCL for connecting Shaung HEP with 66 kV switching station planned at Urni.
- Documents in respect of Forest Clearance and other mandatory clearances for connectivity have been submitted by the Developer.
- The project is planned to be connected with 66 kV switching station at Urni at 66 kV level.
- 66 kV Urni switching station along with 66 kV Urni-Wangtoo D/C line is covered in Tranche-II of ADB loan and is targeted for commissioning in 2016.
- The scheduled date for connectivity for the Shaung HEP is December, 2012 where as Urni Sub station is due for commissioning in 2016. Interim arrangement for evacuation of Shaung HEP till 2016 has already been firmed up during 19th meeting of STU Coordination Committee held on 23.5.2012.

In view of above, we may consider & provide connectivity to Shaung HEP.