

HIMACHAL PRADESH
ELECTRICAL INSPECTORATE

No: HIMVINI / HPPTCL/Charor- Banāla/ 2019-

4277-80

Dated: 1-10-2019

To

✓ The Sr. Manager(Projects),
HPPTCL, Division Sarabai,
Bhunter Distt. Kullu (HP).

Subject:- Inspection of Electrical installations under Regulation 43 of Central Electricity Authority (Measures Relating to Safety and Electric Supply) Regulation, 2010.

Keeping in view, the compliance of the observations submitted by M/s R. S. Infra Projects Pvt. Ltd., H-70, Lane W-10, Sainik Farms, New Delhi-110062 duly signed by the contractor concerned vide letter dated 19-09-2019 alongwith photographs of the observations attended, final approval to energise the Installations referred below is hereby accorded subject to the condition that the consistent compliance of the relevant provisions of Central Electricity Authority (Measures Relating to Safety & Electric Supply), 2010 is made for safe operation and maintenance of the installation.

1. 220 KV D/C Transmission Line from Charor to PGCIL 220/400-KV GIS Sub Station Banāla.

As per provision of Regulation 12, 13, 46, 70 and 30 of Central Electricity Authority (Measures Relating to Safety & Electric Supply), 2010 the owner of the installation under his control shall get his installation periodically inspected and tested from this Inspectorate at an interval not exceeding five years.

(Er. Pankaj Dadwal)

Chief Electrical Inspector,
Himachal Pradesh, Shimla-9
Email: D-ceihp@rediffmail.com

Copy forwarded to the following for information and necessary action:-

1. The DGM (Projects), HPPTCL, Sarabai, Bhunter Distt. Kullu (HP).
2. M/s R. S. Infra Projects Pvt. Ltd., H-70, Lane W-10, Sainik Farms, New Delhi-110062 for information and compliance please.
3. M/s Navdeep Electricals and Civil Engineers, Opp. Post Office, Bhatoli Road Mehatpur Distt. Una (HP).

Chief Electrical Inspector,
Himachal Pradesh, Shimla-9

