Subject: RE: Shifting of the Connectivity of Malana -II HEP to HPPTCL 220 kV Charor to Banala Transmission line and confirmation of Shutdown thereof on 30.09.2019.
From: s.garhia <s.garhia@everestpower.in>
Date: 25-09-2019, 15:38
To: "Er. Sanjay kaushal" <smsarabai@hpptcl.in>
CC: "Bhupesh Uppal<DGM Kullu>" <dgmsarabai@hpptcl.in>, "< GM Projects>" <gmprojects@hpptcl.in>, "Ravinder Kumar Shamra<Managing Director>" <md@hpptcl.in>, "Arun Goyal<Director Project>" <directorprojects@hpptcl.in>, Sarabai Office <sarabai@hpptcl.in>, A Ananda Varma <anandvarma17@everestpower.in>, "'K Seethayya' (kseethayya@gmail.com)'" <kseethayya@gmail.com>, "'ykumar111@gmail.com'" <ykumar111@gmail.com>

Dear Mr Kaushal,

As you are aware that Andritz Hydro is on the job since 7th Sept 2019, and as and when break through is achieved it will be intimated to all concerned. EPPL has not any expertise in doing such jobs therefore not in a position to declare the date when the telemetry communication shall be established. Based on the feedback given by Andritz the possible date was communicated to you. I hope you will appreciate that we are doing the best possible efforts at our end to accomplish the task.

Thanking you,
Regards
S. S. Garhia

From: Er. Sanjay kaushal [mailto:smsarabai@hpptcl.in]
Sent: Wednesday, September 25, 2019 3:21 PM
To: A Ananda Varma; s.garhia
Cc: Bhupesh Uppal<DGM Kullu>; < GM Projects>; Ravinder Kumar Shamra<Managing Director>; Arun Goyal<Director Project>; Sarabai Office
Subject: Shifting of the Connectivity of Malana -II HEP to HPPTCL 220 kV Charor to Banala Transmission line and confirmation of Shutdown thereof on 30.09.2019.

Sir,

"JAI HIND"

In the trailing mail EPPL had intimated that telemetry communication will be completed by 26.09.2019 and requested HPPTCL to re-schedule the shutdown for shifting of the connectivity to 30.09.2019.
Accordingly, shutdown for shifting of the connectivity was discussed in the OCC meeting, held on 16.09.2019 and rescheduled to 30th September, 2019 and stand approved from the OCC meeting.

Moreover telemetry with SLDC / NRLDC from PGCIL Substation Banala over optical link stand already established on 22.09.2019 and necessary certification by the SLDC in this regard has also been issued on 24.09.2019.

Therefore, it is requested to Confirm the readiness of your system by 30.09.2019 through the return mail at the earliest so that HPPTCL could proceed further with the Shutdown on scheduled date i.e. 30.09.2019.

Regards:
Er. Sanjay kaushal,
Sr. Manager(Projects),
HPPTCL, PIU Sarabai, Bhuntar, Distt. Kullu (H.P.)

-------- Forwarded Message --------

Subject: Re: Approved shutdown on 16.09.19 for shifting of connectivity of Malana-II HEP from 220 kV ADHPL Transmission line to HPPTCL 220 kV D/C transmission line from Chharor to Banala.

Date: Mon, 16 Sep 2019 08:12:12 +0000

From: A Ananda Varma <anandvarma17@everestpower.in>

To: Er. Sanjay kaushal <smsarabai@hpptcl.in>

CC: md@hpptcl.in <md@hpptcl.in>, 'Bhupesh Uppal<DGM Kullu>' <dgmsarabai@hpptcl.in>, 'T K Trehan' <tajinder.trehan@lnjbhilwara.com>, 'Pankaj Kapoor' <pankaj.kapoor@lnjbhilwara.com>, pankaj.rana@lnjbhilwara.com <pankaj.rana@lnjbhilwara.com>, sehpsldc@gmail.com <sehpsldc@gmail.com>, controlroom@ptcindia.com <controlroom@ptcindia.com>, pcpatiala@gmail.com <pcpatiala@gmail.com>, nrldcso@gmail.com <nrldcso@gmail.com>, nrldcoutage@gmail.com <nrldcoutage@gmail.com>, nrldcso2@gmail.com <nrldcso2@gmail.com>, s.garhia <s.garhia@everestpower.in>, kseethayya@gmail.com <kseethayya@gmail.com>, Ankit Sood {अंकित सूद} <ankitsood@powergridindia.com>, Arun Kumar Dubb<SM Phojal> <smphojal@hpptcl.in>, Parikshit pal<DM Projects> <dmprojects2@hpptcl.in>, < GM Projects> <gmprojects@hpptcl.in>, Arun Goyal<Director Project> <directorprojects@hpptcl.in>, Rakesh Kumar Dhiman <dgmcomm@hpptcl.in>, Sarabai Office <sarabai@hpptcl.in>, ykumar111@gmail.com <ykumar111@gmail.com>

Sir,
As detailed in the trailing mail the telemetry communication could not be established till date by Andritz Hydro team who are still working on it. The reasons for same could not be ascertained till now. The team is working on it and have requested to give ten days time, such as up to 26.09.2019. Therefore it is requested to take shutdown on 30.09.2019 for switching over to Chhaur-Banala TL.

The delay in getting telemetry communication with NRLDC is not done deliberately but due to technical problems at the end of Andritz Hydro.

Thanks & Regards

Anand Varma
Everest Power Pvt Ltd
Mobile No.: 9805519974

From: Er. Sanjay kaushal <smsarabai@hpptcl.in>
Sent: Monday, September 16, 2019 12:20 PM
To: A Ananda Varma <anandvarma17@everestpower.in>
Cc: md@hpptcl.in <md@hpptcl.in>; 'Bhupesh Uppal<DGM Kullu>' <dgmsarabai@hpptcl.in>; 'T K Trehan' <tajinder.trehan@lnjbhilwara.com>; 'Pankaj Kapoor' <pankaj.kapoor@lnjbhilwara.com>; pankaj.rana@lnjbhilwara.com <pankaj.rana@lnjbhilwara.com>; sehpsldc@gmail.com <sehpsldc@gmail.com>; controlroom@ptcindia.com <controlroom@ptcindia.com>; pcpatiala@gmail.com <pcpatiala@gmail.com>; nrldcso@gmail.com <nrldcso@gmail.com>; nrldcoutage@gmail.com <nrldcoutage@gmail.com>; nrldcso2@gmail.com <nrldcso2@gmail.com>; s.garhia <s.garhia@everestpower.in>; kseethayya@gmail.com <kseethayya@gmail.com>; Ankit Sood {अंकित सूद} <ankitsood@powergridindia.com>; Arun Kumar Dubb<SM Phojal> <smphojal@hpptcl.in>; Parikshit pal<DM Projects> <dmprojects2@hpptcl.in>; < GM Projects> <gmprojects@hpptcl.in>; Arun Goyal<Director Project> <directorprojects@hpptcl.in>; Rakesh Kumar Dhiman

<dgmcomm@hpptcl.in>; Sarabai Office <sarabai@hpptcl.in>
Subject: Re: Approved shutdown on 16.09.19 for shifting of connectivity of Malana-II HEP from 220 kV ADHPL Transmission line to HPPTCL 220 kV D/C transmission line from Chharor to Banala.

Sir,

"JAI HIND"
.
This shutdown was approved
with the consent of EPPL after taking into consideration all the modalities and necessary intimation of this shutdown approval in 162nd OCC meeting was given to you on 13th August, 2019.

With reference to the
trailing Email, for the postponement/ cancellation of this approved shutdown; it is regretted that the approach of EPPL is totally unprofessional and least expected from a reputed Power generating Company.

EPPL were reminded about
the establishment of telemetry of real time data time and again with latest reminder from HPPTCL on 6th September and your confirmation of the same on the same day through Email.

This Cancellation of
this shutdown at the nick of the moment, i.e at 6: 12 hrs of the shutdown date 16.09.2019, will cost heavily to HPPTCL, as all the resources have already been moblised and all Men and Material is at site. Beside the HPPTCL, other IPP's Connected with this
system, who have revised their generation schedule will also be affected. The LILO was to be removed by M/s AD Hydro Transmission Team, who has also mobilized their team and other resources to undertake the job. The entire wasteful expenditure / loss incurred
on this account shall be the responsibility of M/s EPPL.

In the trailing mail,
no timeline has been indicated to establish the telemetry. The shutdown cannot be postponed indefinitely as HPPTCL 220 kV transmission line from Charor to Banala has already been energised successfully on 24.07.2019 and shifting of the connectivity is pending
only because of the telemetry from your end.

It is also informed that
next OCC meeting is scheduled today i.e. 16.09.2019 and the date of next shutdown is to be got approved in this meeting.

Now we propose the shutdown
on 25.09.2019, and the matter will be taken up in the OCC meeting accordingly.
Please confirm the same
through return mail.
Regards:
Er. Sanjay kaushal,
Sr. Manager(Projects),

HPPTCL,
PIU Sarabai, Bhuntar, Distt. Kullu (H.P.)

On 16-09-2019 06:12, A Ananda Varma wrote:

Dear Sir

The Telemetry data communication with NRLDC could not be established till now in-spite if continuous efforts put by Andritz team from 8th Sept 2019 and still on the job.

As per the letter issued by HPSLDC (annexure-1) and with reference to your mail dated on 13.08.2019, the telemetry data communication with NRLDC & HPSLDC is pre-requisite for the scheduled shutdown.

Therefore, in compliance with the attached letters you are requested postpone the scheduled shutdown and oblige.

We are rescheduling our generation schedule from 09:00 Hrs to 24:00 Hrs for minimising the loss.

Thanks & Regards,

Anand Varma
9805519974
Everest Power Pvt Ltd
2x50 MW Malana-II HEP.

From: Er. Sanjay kaushal <smsarabai@hpptcl.in>
Sent: 14 September 2019 12:01
To: Pankaj Kapoor <pankaj.kapoor@lnjbhilwara.com>; T K Trehan <tajinder.trehan@lnjbhilwara.com>; Pankaj Rana <pankaj.rana@lnjbhilwara.com>
Cc: Bhupesh Uppal<DGM Kullu> <dgmsarabai@hpptcl.in>; < GM Projects> <gmprojects@hpptcl.in>; A Ananda Varma <anandvarma17@everestpower.in>
Subject: Fwd: Approved shutdown on 16.09.19 for shifting of connectivity of Malana-II HEP from 220 kV ADHPL Transmission line to HPPTCL 220 kV D/C transmission line from Chharor to Banala.

Sir,
"JAI HIND"
Shutdown for the shifting of the connectivity of Malana-II HEP from 220 kV ADHPL transmission line to HPPTCL 220 kV Charor to Banala transmission line has been approved in the 162nd OCC meeting for 16.09.2019.
This is for your information and necessary action please.
Regards:
Er. Sanjay Kaushal,
SM PIU Sarabai.

-------- Forwarded Message --------
Subject: Approved shutdown on 16.09.19.
Date: Thu, 12 Sep 2019 13:11:12 +0530
From: Se Sldc <sehpsldc@gmail.com>
To: Er. Sanjay kaushal <smsarabai@hpptcl.in>
CC: Power Controller <pcshimla2003@gmail.com>

Dear sir,
As discussed please find attached herewith the list of approved shutdown in r/o 220 kV Nalagarh-Charor and 220 kV Phozal-Charor lines.

--

http://ww

Superintending Engineer,
HP State Load Despatch Centre,
Govt. of HP, Totu, Shimla-11
www.hpsldc.com

--

Regards:
Er. Sanjay Kaushal,
Sr. Manager(Projects)
HPPTCL, PIU Sarabai.
Bhuntar, Distt. Kullu (H.P.) 175125
Mobile: 9418450833

Report for Outage Approval by OCC meeting no. 162												
Sr.No	Request by	Element Owner	Element Type	Element Name	Mode	Reason	Outage Request				Total Hours	Last OCC Number
							From Date	From Time	To Date	To Time		
1	NTPC	NTPC	GENCO	Tanda TPS-U1/110	CONTINUOUS	Annual Overhaul	2019-09-01	09:30	2019-09-25	18:26	584.93	157
2	NTPC	NTPC	GENCO	Rihand TPS-U2/500	CONTINUOUS	Rihand U#2: Over haul- Boiler +PAPH Modification + ECO Coil replacement	2019-08-31	00:00	2019-10-19	23:59	1199.98	145
3	NTPC	NTPC	GENCO	Dadri NCTPS-U4/210	CONTINUOUS	BOILER OH & RLA OF CRITICAL HI Pressure PIPING	2019-08-20	09:30	2019-09-12	18:30	561	-
4	NTPC	POWERGRID	HVDC	RIHAND-DADRI POLE-2/500	CONTINUOUS	NTPC Rihand- PGCIL Rihand, 400 KV HVDC Line-2 : for replacement of 3 no. 400 KV CTs on grounds of ageing (>20 years old) and annual maintenance of bay equipment's	2019-09-02	08:30	2019-09-04	18:30	58	-
5	POWERGRID	POWERGRID	HVDC	AGRA-BISHWANATH CHARIALI POLE-1/800	DAILY	VESDA Testing, Cleaning, C & Tan delta of DC side bushing	2019-09-02	09:00	2019-09-03	18:00	18	158
6	POWERGRID	POWERGRID	HVDC	AGRA-BISHWANATH CHARIALI POLE-2/800	DAILY	AMP of Valve cooling plant, VESDA Testing, Cleaning, CNG set load test, C & Tan delta of DC side bushing at HVDC Agra	2019-09-04	09:00	2019-09-07	18:00	36	158
7	POWERGRID	POWERGRID	HVDC	AGRA-ALIPURDUAR POLE-3/800	DAILY	VESDA Testing, cleaning .	2019-09-09	09:00	2019-09-09	18:00	9	-
8	POWERGRID	POWERGRID	HVDC	Agra-APD Pole 4/1500	DAILY	VESDA Testing, Cleaning, CNG set load test at HVDC Agra	2019-09-10	09:00	2019-09-11	18:00	18	-
9	POWERGRID	POWERGRID	HVDC	AGRA-BISHWANATH CHARIALI POLE-1/800	CONTINUOUS	De-stringing of existing line & tapping of new diverted section at Tower No.-3451 & 3474 due to Diversion Work of 800 KV HVDC BNC-Agra TL infringing the corridor of 'Purvanchal Expressway' (UPEIDA) (Diversion Line Sketch enclosed).All the four Poles at Agra shall be out during the period as work to be carried out on both the lines.	2019-08-30	06:00	2019-09-03	18:00	108	158
10	POWERGRID	POWERGRID	HVDC	AGRA-BISHWANATH CHARIALI POLE-2/800	CONTINUOUS	De-stringing of existing line & tapping of new diverted section at Tower No.-3451 & 3474 due to Diversion Work of 800 KV HVDC BNC-Agra TL infringing the corridor of 'Purvanchal Expressway' (UPEIDA) (Diversion Line Sketch enclosed).All the four poles at Agra shall be out of service during the period as work to be carried out in both the lines.	2019-08-30	06:00	2019-09-03	18:00	108	158

11	POWERGRID	POWERGRID	HVDC	AGRA-ALIPURDUAR POLE-3/800	CONTINUOUS	De-stringing of existing line & tapping of new diverted section at Tower No.-3451 & 3474 due to Diversion Work of 800 KV HVDC BNC-Agra TL infringing the corridor of 'Purvanchal Expressway' (UPEIDA) (Diversion Line Sketch enclosed).All the four poles at Agra shall be out of service during the period as work to be carried out in both the lines.	2019-08-30	06:00	2019-09-03	18:00	108	-
12	POWERGRID	POWERGRID	HVDC	Agra-APD Pole 4/1500	CONTINUOUS	De-stringing of existing line & tapping of new diverted section at Tower No.-3451 & 3474 due to Diversion Work of 800 KV HVDC BNC-Agra TL infringing the corridor of 'Purvanchal Expressway' (UPEIDA) (Diversion Line Sketch enclosed).All the four poles at Agra shall be out of service during the period as work to be carried out in both the lines.	2019-08-30	06:00	2019-09-03	18:00	108	-
13	POWERGRID	POWERGRID	HVDC	AGRA-BISHWANATH CHARIALI POLE-1/800	DAILY	for fixing of broken jump conductor and tighting of jumpers N&B s. S/D applied by ER1	2019-09-04	10:00	2019-09-04	14:00	4	158
14	POWERGRID	POWERGRID	HVDC	KURUKSHETRA-CHAMPA POLE-1/800	DAILY	For Pole-3 Commissioning works: For testing of bipole with Pole-3 under construction with new sofware updated after testing in May. Some hardware modification also need to be carried out.	2019-08-21	08:00	2019-08-21	20:00	12	156
15	POWERGRID	POWERGRID	HVDC	KUREKSHETRA -CHAMPA POLE -II/800	DAILY	For Pole-3 Commissioning works: For testing of bipole with Pole-3 under construction with new sofware updated after testing in May. Some hardware modification also need to be carried out.	2019-08-21	08:00	2019-08-21	20:00	12	158
16	POWERGRID	POWERGRID	HVDC	AGRA-BISHWANATH CHARIALI POLE-2/800	DAILY	for fixing of broken jump conductor and tighting of jumpers N&B s.. S/D applied by ER1 for dt. 06.09 but tsop denied the same due to software constraint	2019-09-08	10:00	2019-09-08	14:00	4	158
17	ADHPL	ADHPL	LINE	PHOZAL (220KV)-CHHAUR (220KV)	DAILY	Interconnection of 220kV Charor-Banala TL with 220/132kV Substation Chhaur.	2019-09-16	09:00	2019-09-16	18:00	9	159
18	ADHPL	ADHPL	LINE	NALLAGARH (220KV)-CHHAUR (220KV)	DAILY	Interconnection of 220kV Charor-Banala TL with 220/132kV Substation Chhaur. (For the shifting of connectivity of Malana-II HEP from ADHPL transmission line to newly constructed transmission line Charor-Banala-II)	2019-09-16	09:00	2019-09-16	18:00	9	159
19	BBMB	BBMB	LINE	BHIWANI BBMB (220KV)-CHARKHI DADRI (220KV)1	CONTINUOUS	Replacement of breaker at Bhiwani Sub station	2019-09-16	08:00	2019-09-19	17:00	81	156
20	BBMB	BBMB	LINE	BHIWANI BBMB (220KV)-CHARKHI DADRI (220KV)2	CONTINUOUS	Replacement of breaker at Bhiwani and dadri Sub station	2019-09-23	08:00	2019-09-26	17:00	81	156
21	BBMB	BBMB	LINE	BARNALA (220KV)-LEHRA MOHABAT (200KV)	DAILY	Half yearly mtc of line	2019-09-24	08:00	2019-09-24	17:00	9	157
22	BBMB	BBMB	LINE	Bhatinda-LEHRA MOHABAT (200KV)	DAILY	Half yearly mtc of line	2019-09-27	08:00	2019-09-27	17:00	9	152

23	BBMB	BBMB	LINE	BHAKRA RIGHT (220KV)-GANGUWAL (220KV)1	DAILY	Half yearly mtc of sub station equipments	2019-09-19	08:00	2019-09-20	17:00	18	160
24	BBMB	PSTCL	LINE	MISS-MOHALI (220KV)	DAILY	Half yearly mtc of sub station equipments	2019-09-23	08:00	2019-09-24	17:00	18	157
25	BBMB	BBMB	LINE	BARNALA (220KV)-SANGRUR (220KV)	DAILY	Half yearly mtc of line	2019-09-20	08:00	2019-09-20	17:00	9	158
26	DTL	DTL	LINE	BAMNOLI (400KV)-JHATIKALA (400KV)1	DAILY	For General Maintenance of Line as per PMS Schedule.	2019-09-05	06:00	2019-09-05	17:30	11.5	156
27	DTL	DTL	LINE	BAMNOLI (400KV)-JHATIKALA (400KV)2	DAILY	For General Maintenance of Line as per PMS Schedule.	2019-09-06	06:00	2019-09-06	17:30	11.5	159
28	DTL	DTL	LINE	MANDOLA (400KV)-BAWANA-DTL (400KV)1	DAILY	Jumper tightning of tension towers , Broken spacers and tan Delta testing of CVT to be changed.	2019-09-06	08:00	2019-09-06	17:00	9	154
29	DTL	DTL	LINE	MANDOLA (400KV)-BAWANA-DTL (400KV)1	DAILY	Jumper tightening of tension towers , Broken spacers to be changed.	2019-09-09	08:00	2019-09-09	17:00	9	154
30	DTL	DTL	LINE	MANDOLA (400KV)-BAWANA-DTL (400KV)2	DAILY	Jumper tightning of tension towers and Broken spacers and tan Delta testing of CVT to be changed.	2019-09-11	08:00	2019-09-11	17:00	9	156
31	DTL	DTL	LINE	MANDOLA (400KV)-BAWANA-DTL (400KV)2	DAILY	Jumper tightening of tension towers and Broken spacers to be changed.	2019-09-12	08:00	2019-09-12	17:00	9	156
32	HVPNL	POWERGRID	LINE	BHIWANI-PG (400KV)-KABULPUR (400KV)	DAILY	Annual Maintenance & testing of Bay equipment	2019-09-18	08:00	2019-09-18	16:00	8	158
33	HVPNL	POWERGRID	LINE	KABULPUR (400KV)-BAHADURGARH (400KV)	DAILY	Annual Maintenance & testing of Bay equipment	2019-09-20	08:00	2019-09-20	16:00	8	158
34	HVPNL	KT JHAJJAR	LINE	KABULPUR (400KV)-DEEPALPUR (400KV)1	DAILY	General Maintenance	2019-09-24	08:00	2019-09-24	13:00	5	159
35	HVPNL	KT JHAJJAR	LINE	KABULPUR (400KV)-DEEPALPUR (400KV)2	DAILY	General Maintenance	2019-09-25	08:00	2019-09-25	16:00	8	159
36	HVPNL	HVPNL	LINE	DAULTABAD (400KV)-JHAJJAR-APCPL (400KV)1	DAILY	Replacement of 1 No isolator 40289 B of Daultabad-Dhanonda ckt 1, Shutdown is require along with 400 KV Bus bar-1 due to defective Tie breaker no 411	2019-08-23	10:00	2019-08-23	17:00	7	157
37	HVPNL	HVPNL	LINE	DHANONDA (400KV)-DAULTABAD (400KV)2	DAILY	Preventive maintenance to prevent probable hot points nodes observed during thermo vision scanning on dated 05.08.19	2019-08-27	10:00	2019-08-27	17:00	7	160
38	HVPNL	HVPNL	LINE	DHANONDA (400KV)-DAULTABAD (400KV)1	DAILY	Preventive maintenance to prevent probable hot points nodes observed during thermo vision scanning on dated 05.08.19	2019-09-03	10:00	2019-09-03	17:00	7	160

39	HVPNL	KT JHAJJAR	LINE	JHAJJAR-CLP (400KV)-KABULPUR (400KV)I	DAILY	Bay equipment maintenance	2019-08-22	07:00	2019-08-22	19:00	12	157
40	HVPNL	KT JHAJJAR	LINE	JHAJJAR-CLP (400KV)-KABULPUR (400KV)II	DAILY	Bay equipment maintenance	2019-08-23	07:00	2019-08-23	19:00	12	152
41	JKPDD	POWERGRID	LINE	KISHENPUR (400KV)-NEW WANPOH (400KV)II	CONTINUOUS	LILO, Taping and Jumping	2019-09-23	09:00	2019-09-28	18:00	129	157
42	NHPC	PKTCL	LINE	PARBATI-2 (400KV)-ParbatiPooling-BANALA (400KV)1	DAILY	Testing & Commissioning of Unit#3 & Unit#4 for conducting OCC & SCC Test of these units	2019-08-20	09:30	2019-08-22	18:32	27.09	158
43	NHPC	PKTCL	LINE	PARBATI-3 (400KV)-ParbatiPooling-BANALA (400KV)2	DAILY	Testing & Commissioning of Unit#3 & Unit#4 for conducting OCC & SCC Test of these units.	2019-08-22	09:30	2019-08-24	18:30	27	153
44	NTPC	POWERGRID	LINE	UNCHAHAR (220KV)-KANPUR (400KV)III	CONTINUOUS	220 KV Unchahar-Kanpur Line-3: Annual bay maintenence.	2019-09-03	08:30	2019-09-04	18:30	34	152
45	NTPC	POWERGRID	LINE	UNCHAHAR (220KV)-KANPUR (400KV)IV	CONTINUOUS	220 KV Unchahar-Kanpur line-3 : annual maintenence.	2019-09-05	08:30	2019-09-06	18:30	34	159
46	NTPC	POWERGRID	LINE	SINGRAULI NTPC (400KV)-LUCKNOW (Sarojini Nagar) 400-UP	CONTINUOUS	Singrauli-Lucknow 400 KV Line- for 400kV Breaker Replacement. Line will be taken on Transfer Bus-1. Main breaker Permit is required. Last day shutdown required of Line to take main breaker in service	2019-09-02	08:30	2019-09-05	18:30	82	161
47	NTPC	POWERGRID	LINE	SINGRAULI NTPC (400KV)-ALLAHABAD (400KV)I	CONTINUOUS	400kV Singrauli Allahabad Line-1-for 400kV Breaker Replacement. Line will be taken on Transfer Bus-1. Main breaker Permit is required. Last day shutdown required of Line to take main breaker in service.	2019-09-06	08:30	2019-09-09	18:30	82	158
48	NTPC	POWERGRID	LINE	SINGRAULI NTPC (400KV)-ANPARA-B (400KV)	CONTINUOUS	400kV Singrauli Anpara Line-1- for 400kV Breaker Replacement. Line will be taken on Transfer Bus-1. Main breaker Permit is required. Last day shutdown required of Line to take main breaker in service.	2019-09-10	08:30	2019-09-13	18:30	82	161
49	NTPC	NTPC	LINE	DADRI-THERMAL (400KV)-LONI-HARSHVIHAR (400KV)2	DAILY	To attend oil leakage in 125MVAR shunt reactor . 400KV Dadri-Harshvihar-2 line conductors is running just above the shunt reactor and thus its shutdown is mandatory for safe working on shunt reactor.	2019-08-24	08:00	2019-08-24	18:00	10	161
50	NTPC	PKTCL	LINE	KOLDAM (400KV)-LUDHIANA (400KV)2	DAILY	Disc Insulator replacement R-Phase Ludhiana line Bay#13 in Koldam Switchyard	2019-09-17	09:00	2019-09-17	17:30	8.5	153
51	NTPC	PKTCL	LINE	KOLDAM (400KV)-LUDHIANA (400KV)2	DAILY	Disc Insulator replacement B-Phase Ludhiana line Bay#13 in Koldam Switchyard	2019-09-19	09:00	2019-09-19	17:30	8.5	153
52	NTPC	POWERGRID	LINE	ANTA GPS (220KV)-BHILWARA (220KV)1	CONTINUOUS	220 kV Breaker replacement work	2019-09-02	09:00	2019-09-14	18:00	297	159
53	NTPC	POWERGRID	LINE	ANTA GPS (220KV)-BHILWARA (220KV)2	CONTINUOUS	220 kV Breaker replacement work	2019-09-15	12:18	2019-09-27	12:18	288	159

54	NTPC	POWERGRID	LINE	ANTA GPS (220KV)-LALSOT (220KV)(PG)	CONTINUOUS	220 kV Breaker replacement work	2019-09-30	09:00	2019-10-05	18:00	129	158
55	POWERGRID	POWERGRID	LINE	BALIA(400KV)-BIHARSHARIF-ER (400KV)I	DAILY	For replacement of Neutral Bushing of 50MVAR BHEL make Line Reactor at Ballia end.	2019-09-03	10:00	2019-09-03	18:00	8	157
56	POWERGRID	POWERGRID	LINE	FATEHPUR-PG (765 KV)-SASARAM-ER (765KV)	DAILY	For AMP & Tightening Work of Line Reactor and Line Side Equipments at 765kV fatehpur S/S.	2019-09-14	09:00	2019-09-14	18:00	9	161
57	POWERGRID	POWERGRID	LINE	BARH-ER (400KV)-GORAKHPUR-PG (400KV)1	DAILY	AMP of Line Bay equipments at PGCIL Gorakhpur S/s. Line Liloed at motihari GIS and now line is gorakhpur-Motihari. S/D is required for Gorakhpur-Motihari#1	2019-09-02	09:00	2019-09-02	17:00	8	-
58	POWERGRID	POWERGRID	LINE	BARH-ER (400KV)-GORAKHPUR-PG (400KV)2	DAILY	AMP of Line Bay equipments at PGCIL Gorakhpur S/s. Line Liloed at motihari GIS and now line is gorakhpur-Motihari. S/D is required for Gorakhpur-Motihari#2	2019-09-03	10:00	2019-09-03	18:00	8	-
59	POWERGRID	POWERGRID	LINE	Orai (765KV)-JABALPUR1	DAILY	FOR AMP of line side Equipment at Orai end	2019-09-10	09:00	2019-09-10	17:00	8	159
60	POWERGRID	POWERGRID	LINE	Orai (765KV)-JABALPUR2	DAILY	FOR REPAIRING B-PH SPARE ISOLATOR AND B-PH LINE EARTH SWITCH at Orai end	2019-09-04	09:00	2019-09-05	17:00	16	159
61	POWERGRID	POWERGRID	LINE	Orai (765KV)-ALIGARH-PG (765KV)I	DAILY	AMP of line side equipment at Aligarh Substation	2019-09-02	09:00	2019-09-02	18:00	9	160
62	POWERGRID	POWERGRID	LINE	Orai (765KV)-ALIGARH-PG (765KV)II	DAILY	AMP of line side equipment at Aligarh Substation	2019-09-03	09:00	2019-09-03	18:00	9	160
63	POWERGRID	POWERGRID	LINE	AGRA-PG (765KV)-ALIGARH-PG (765KV)S/C	DAILY	AMP of line side equipment at Aligarh Substation	2019-09-04	09:00	2019-09-04	18:00	9	160
64	POWERGRID	POWERGRID	LINE	ALIGARH-PG (765KV)-GREATER NOIDA(765 KV)S/C	DAILY	AMP of line side equipment at Aligarh Substation	2019-09-05	09:00	2019-09-05	18:00	9	155
65	POWERGRID	POWERGRID	LINE	KANPUR GIS (765KV)-ALIGARH-PG (765KV)S/C	DAILY	AMP of line side equipment at Aligarh Substation	2019-09-06	09:00	2019-09-06	18:00	9	161
66	POWERGRID	POWERGRID	LINE	ALIGARH-PG (765KV)-JHATIKALA(765 KV)	DAILY	AMP of line side equipment at Aligarh Substation	2019-09-07	09:00	2019-09-07	18:00	9	158
67	POWERGRID	POWERGRID	LINE	MEERUT (765KV)-MOGA(765KV)	DAILY	Construction Work :Erection and Testing of equipment of Koteshwer Line-1 Reactor LA .Line s/d due to induction problem.	2019-09-08	09:00	2019-09-09	18:00	18	159
68	POWERGRID	POWERGRID	LINE	MEERUT (765KV)-BHIWANI-PG (765 KV)	DAILY	Construction Work :Erection and Testing of equipment of 765 kV ICT-III .Line s/d due to induction problem.	2019-09-14	09:00	2019-09-15	18:00	18	161
69	POWERGRID	POWERGRID	LINE	AGRA-PG (765KV)-JHATIKALA(765 KV)	DAILY	For diversion work due to DFCC	2019-09-01	08:00	2019-09-15	19:00	165	159

70	POWERGRID	POWERGRID	LINE	BAREILY-PG (400KV)-SHAHJAHANPUR (400KV)I	DAILY	CVT REPLACEMENT WORK at Bareilly S/S	2019-09-03	09:00	2019-09-03	18:00	9	153
71	POWERGRID	POWERGRID	LINE	KANPUR (400KV)-AGRA-PG (400KV)	DAILY	FOR Line Reactor TESTING & Variable Frequency Tan Delta OF HV BUSHINGS	2019-09-02	09:00	2019-09-02	18:00	9	161
72	POWERGRID	POWERGRID	LINE	MORADABAD (400KV)-HAPUR	CONTINUOUS	CT REPLACEMENT WORK at Moradabad S/s	2019-09-19	09:00	2019-09-21	18:00	57	160
73	POWERGRID	POWERGRID	LINE	VARANASI (765KV)-FATEHPUR-PG (765 KV)	DAILY	For AMP & Tightening Work of Line Reactor and Line Side Equipments at 765kV fatehpur S/S.	2019-09-02	09:00	2019-09-02	18:00	9	156
74	POWERGRID	POWERGRID	LINE	SINGRAULI NTPC (400KV)-FATEHPUR - PG (400KV)	DAILY	For taking Reactor out of service for AMP, Corona Shield Modification in HV Bushing ,CC-CL plate replacement work and internal Inspection Work at 765kV fatehpur S/S.	2019-09-23	10:00	2019-09-23	11:00	1	160
75	POWERGRID	POWERGRID	LINE	PHAGI (765KV)-GWALIOR-WR (765KV)1	DAILY	Replacement of suspension and tension string (Porcelain) with Polymer insulator (String) in main and Tie bay along with associated Bus Gantry. Dia to be kept Open at both ends.S/D by WR-II	2019-09-25	06:00	2019-09-25	18:30	12.5	159
76	POWERGRID	POWERGRID	LINE	PHAGI (765KV)-GWALIOR-WR (765KV)2	DAILY	For alignment of isolator and rectification of interlock problem in isolator at Gwalior dia to be kept Open at both ends & ckt-1 A/R OFF. S/D by WR-II	2019-09-17	08:30	2019-09-17	18:30	10	159
77	POWERGRID	POWERGRID	LINE	SINGRAULI NTPC (400KV)-FATEHPUR - PG (400KV)	DAILY	For taking Reactor into service after AMP, Corona Shield Modification in HV Bushing,CC-CL plate replacement work and internal Inspection Work at 765kV fatehpur S/S.	2019-09-30	17:30	2019-09-30	18:30	1	160
78	POWERGRID	POWERGRID	LINE	SINGRAULI NTPC (400KV)-ALLAHABAD (400KV)I	DAILY	For repairing of snapped Earthwire at Location no. 317. in mirzapur	2019-09-20	08:00	2019-09-20	17:00	9	158
79	POWERGRID	POWERGRID	LINE	SINGRAULI NTPC (400KV)-ALLAHABAD (400KV)II	DAILY	For repairing of snapped Earthwire at Location no. 291 in Mirzapur	2019-09-25	08:00	2019-09-25	17:00	9	161
80	POWERGRID	POWERGRID	LINE	DHAULIGANGA (220KV)-BAREILY-CB GANJ (220KV)II	DAILY	To take the 25 MVAR Line Reactor out of service for off line oil filtration of the reactor at dhauliganga end	2019-09-01	10:00	2019-09-01	10:58	0.97	157
81	POWERGRID	POWERGRID	LINE	DHAULIGANGA (220KV)-BAREILY-CB GANJ (220KV)II	DAILY	To take the 25MVAr Reactor in service after Reactor oil filteration at dhauliganga end.	2019-09-05	10:00	2019-09-05	11:00	1	157
82	POWERGRID	POWERGRID	LINE	LUCKNOW-Kursi Road (400KV) PG-UNNAO (400KV)1	DAILY	Main-1 Distance relay Replacement work at Lucknow	2019-09-06	10:00	2019-09-06	15:00	5	159
83	POWERGRID	POWERGRID	LINE	LUCKNOW-Kursi Road (400KV) PG-UNNAO (400KV)2	DAILY	Main-1 Distance relay Replacement work at Lucknow.	2019-09-07	10:00	2019-09-07	18:00	8	155

84	POWERGRID	POWERLINK	LINE	GORAKHPUR-PG (400KV)-LUCKNOW-Kursi Road (400KV) PGI	DAILY	Main-1 Distance relay Replacement work at Lucknow	2019-09-10	10:00	2019-09-10	18:00	8	161
85	POWERGRID	POWERGRID	LINE	LUCKNOW-Kursi Road (400KV) PG-GORAKHPUR-PG (400KV)IV	DAILY	Main-1 Distance relay Replacement work at Lucknow.	2019-09-09	10:00	2019-09-09	18:00	8	161
86	POWERGRID	POWERGRID	LINE	LUCKNOW-Kursi Road (400KV) PG-UNNAO (400KV)1	DAILY	Main-1 Distance relay Replacement work at unnao	2019-09-14	10:00	2019-09-14	18:00	8	159
87	POWERGRID	POWERGRID	LINE	LUCKNOW-Kursi Road (400KV) PG-UNNAO (400KV)2	DAILY	Main-1 Distance relay Replacement work at unnao	2019-09-15	10:00	2019-09-15	18:00	8	155
88	POWERGRID	POWERGRID	LINE	BHIWANI-PG (765 KV)-PHAGI (765KV)1	DAILY	For Line Maintenance work	2019-09-16	08:00	2019-09-17	18:00	20	159
89	POWERGRID	POWERGRID	LINE	MOGA(765KV)-BHIWANI-PG (765 KV)	DAILY	For Line Maintenance work	2019-09-18	08:00	2019-09-18	18:00	10	158
90	POWERGRID	POWERGRID	LINE	AGRA-PG (765KV)-GWALIOR-WR (765KV)I	DAILY	Replacement of suspension and tension string (porcelain) with polymer insulator (string) in main & Tie bay along with associated bus gantry (dia to be kept open at both end).S/d requested by Wr-II	2019-09-23	06:00	2019-09-23	18:00	12	159
91	POWERGRID	POWERGRID	LINE	AGRA-PG (765KV)-GWALIOR-WR (765KV)II	DAILY	Replacement of suspension and tension string (Porcelain) with Polymer insulator (string) in main & tie bay along with associated Bus Gantry (dia to be kept open at both end). S/d requested by Wr-II.	2019-09-24	06:00	2019-09-24	18:00	12	159
92	POWERGRID	POWERGRID	LINE	Orai (765KV)-GWALIOR-WR (765KV)S/C	DAILY	For alignment of Isolator and Rectification of Interlock problem in Isolator (dia to be kept open at both end). S/d requested by WR-II.	2019-09-19	09:00	2019-09-19	18:00	9	159
93	POWERGRID	POWERGRID	LINE	Orai (765KV)-JABALPUR2	DAILY	Taking oil samples from 765kV ABB make Bushing (dia to be kept open at both ends).S/d requested by WR-II.	2019-09-03	10:00	2019-09-03	12:00	2	159
94	POWERGRID	POWERGRID	LINE	ALLAHABAD (400KV)-SASARAM-ER (400KV)	DAILY	For Replacement of insulators at Road/Rail/River/Power Line Crossings and Relay Retrofitting S/D applied by ER1	2019-09-05	09:00	2019-09-10	18:00	54	154
95	POWERGRID	POWERGRID	LINE	SASARAM-ER (400KV)-VARANASI (400KV)	DAILY	Replacement of insulators at Road/Rail/River/Power Line Crossings and Relay Retrofitting. S/D applied by ER1	2019-09-10	09:00	2019-09-15	18:00	54	154
96	POWERGRID	UPPTCL	LINE	SAHUPURI (220KV)-PUSAULI BSEB-ER (220KV)+BSEB	DAILY	To facilitate the S/D of ICT-I for shifting of transformer for Transformer Retrofitting Work. S/D applied by ER1	2019-09-05	09:00	2019-09-08	18:00	36	161
97	POWERGRID	POWERGRID	LINE	GAYA-ER (765KV)-BALIA (765KV)	DAILY	For replacement of insulators damaged by miscreant . S/D applied by ER1	2019-09-26	09:00	2019-09-27	18:00	18	157

98	POWERGRID	POWERGRID	LINE	FATEHPUR-PG (765 KV)-SASARAM-ER (765KV)	DAILY	For Tower strengthening work. S/D applied by ER1	2019-09-01	08:00	2019-09-13	18:00	130	161
99	POWERGRID	POWERGRID	LINE	FATEHPUR-PG (765 KV)-SASARAM-ER (765KV)	DAILY	For Tower strengthening work. S/D applied by ER1	2019-09-15	08:00	2019-09-20	18:00	60	161
100	POWERGRID	POWERGRID	LINE	KISHENPUR (400KV)-NEW WANPOH (400KV)I	DAILY	For AMP of line equipment.	2019-09-11	10:00	2019-09-11	14:00	4	152
101	POWERGRID	POWERGRID	LINE	KISHENPUR (400KV)-MOGA (400KV)2	DAILY	For removal of aviation globes and earth wire between loc. no. 640 to 647 for OPGW laying under ULDC scheme.	2019-08-28	09:30	2019-08-30	18:30	27	161
102	POWERGRID	POWERGRID	LINE	ROORKEE (400KV)-SAHARANPUR (400KV)1	DAILY	For replacement of porcelain Insulator with Polymer Insulator in 400kV Switchyard at Saharanpur	2019-09-02	09:00	2019-09-04	18:00	27	156
103	POWERGRID	POWERGRID	LINE	BAGHPAT (400KV)-SAHARANPUR (400KV)	DAILY	For replacement of porcelain Insulator with Polymer Insulator in 400kV Switchyard at Saharanpur	2019-09-05	09:00	2019-09-07	17:00	24	160
104	POWERGRID	POWERGRID	LINE	MEERUT (400KV)-MANDOLA (400KV)II	DAILY	420 89A isolator jumper disconnection for isolator retrofitment under ADD CAP	2019-09-22	10:00	2019-09-22	17:00	7	161
105	POWERGRID	POWERGRID	LINE	MEERUT (400KV)-MANDOLA (400KV)II	DAILY	Jumpering of bay 420 89A isolator after retrofitmemnt under ADD CAP	2019-09-27	14:00	2019-09-27	17:00	3	161
106	POWERGRID	POWERGRID	LINE	MEERUT (400KV)-KOTESHWAR (400KV)1	CONTINUOUS	Restoration of Tower Location No. 58 of 400 kV Koteshwar-Meerut-1 line which involves erection of 02 Nos new Tower (57A & 58 A), destringing and stringing of 1.3 Km in three spans(Tower span 57-57A, 57A-58A, 58A-59). Above Shutdown of 11 days is required for dismantling of old defective tower no. 58, destringing between 57 to 58, 58 to 59 and stringing between 57 to 57A , 57A to 58 A and 58A to 59.	2019-09-16	09:00	2019-09-26	17:00	248	155
107	POWERGRID	POWERGRID	LINE	AJMER(400KV)-AJMER (400KV)I	DAILY	Line terminal elements AMP work & NTAMC operation checking of isolators	2019-09-02	09:00	2019-09-02	13:00	4	156
108	POWERGRID	POWERGRID	LINE	AJMER(400KV)-AJMER (400KV)II	DAILY	Line terminal elements AMP work & NTAMC operation checking of isolators	2019-09-03	09:00	2019-09-03	13:00	4	156
109	POWERGRID	POWERGRID	LINE	AGRA-PG (400KV)-BALLABGARH-PG (400KV)	DAILY	S/D required for testing of new retrofitted relays of reactor protection,Auto Reclose relay& AMP works	2019-08-26	09:00	2019-08-26	14:00	5	161
110	POWERGRID	POWERGRID	LINE	KANPUR (400KV)-BALLABGARH-PG (400KV)I	DAILY	S/D required for testing of new retrofitted relays of reactor protection,Auto Reclose relay& AMP works	2019-08-28	09:00	2019-08-28	14:00	5	160
111	POWERGRID	POWERGRID	LINE	KANPUR (400KV)-BALLABGARH-PG (400KV)II	DAILY	S/D required for testing of new retrofitted relays of reactor protection,Auto Reclose relay& AMP works	2019-08-30	09:00	2019-08-30	14:00	5	156

112	POWERGRID	POWERGRID	LINE	KANPUR (400KV)-BALLABGARH-PG (400KV)III	DAILY	S/D required for testing of new retrofitted relays of reactor protection,Auto Reclose relay& AMP works	2019-08-31	09:00	2019-08-31	14:00	5	160
113	POWERGRID	POWERGRID	LINE	JAIPUR South (400KV)-RAPP D (400KV)	DAILY	AMP work eg-Fixing Jumper bolt,tightening of CC ring & Grading Ring etc	2019-09-09	08:00	2019-09-10	18:00	20	-
114	POWERGRID	POWERGRID	LINE	KOTA (400KV)-JAIPUR South (400KV)	DAILY	AMP work eg-Fixing Jumper bolt,tightening of CC ring & Grading Ring etc	2019-09-11	08:00	2019-09-12	18:00	20	-
115	POWERGRID	POWERGRID	LINE	Orai (765KV)-SATNAS/C	DAILY	For AMP Works. S/D requested by WR-2	2019-09-02	09:00	2019-09-02	18:00	9	159
116	POWERGRID	JSW	LINE	KARCHAM WANGTOO (400KV)-KALA AMBI	CONTINUOUS	For Commissioning of 400/220/66 kV GIS Substation Wangtoo of STU (HPPTCL) with D/C LILO of 400kV Wangtoo-Abdullapur(Already LILO at Kala Amb TL) at Wangtoo, Distt. Kinnaur (HP).	2019-09-11	08:00	2019-09-12	18:00	34	156
117	POWERGRID	JSW	LINE	KARCHAM WANGTOO (400KV)-KALA AMBII	DAILY	For Commissioning of 400/220/66 kV GIS Substation Wangtoo of STU (HPPTCL) with D/C LILO of 400kV Wangtoo-Abdullapur(Already LILO at Kala Amb TL) at Wangtoo, Distt. Kinnaur (HP).	2019-09-11	08:00	2019-09-12	18:00	20	156
118	PTCUL	PTCUL	LINE	SRINAGAR_UK (400KV)-Srinagar HEP-ALAKANANDA (400KV)1	DAILY	For maintenance line and lopping Chopping of tree branches in line corridor.	2019-09-06	10:00	2019-09-07	17:00	14	160
119	PTCUL	PTCUL	LINE	SRINAGAR_UK (400KV)-Srinagar HEP-ALAKANANDA (400KV)2	DAILY	For maintenance line and lopping Chopping of tree branches in line corridor.	2019-09-09	10:00	2019-09-10	17:00	14	160
120	PTCUL	PTCUL	LINE	MORADABAD (400KV)-KASHIPUR (400KV)	DAILY	For preventive maintenance of line including tightening of jumper and fixing of new spacer and other items if found defective.	2019-09-03	10:00	2019-09-03	17:00	7	158
121	PTCUL	PTCUL	LINE	ROORKEE (400KV)-RISHIKESH (400KV)	DAILY	For testing & Commissioning of Bus Bar protection panel under PSDF Scheme.	2019-09-11	10:00	2019-09-11	15:00	5	160
122	PTCUL	PTCUL	LINE	RISHIKESH (400KV)-NEHTAUR (220KV)1	DAILY	For testing & Commissioning of Bus Bar protection panel under PSDF Scheme.	2019-09-11	10:00	2019-09-11	15:00	5	160
123	RRVPN	RRVPN	LINE	ANTA(765KV)-PHAGI (765KV)I	DAILY	FOR Halfyearly Maintenance work (Tightning of Nuts & Bolts of Clamp, Fixures & Jumpers).	2019-09-17	09:00	2019-09-18	18:00	18	159
124	RRVPN	RRVPN	LINE	ANTA(765KV)-PHAGI (765KV)II	DAILY	FOR Halfyearly Maintenance work (Tightning of Nuts & Bolts of Clamp, Fixures & Jumpers).	2019-09-19	09:00	2019-09-20	18:00	18	158
125	RRVPN	RRVPN	LINE	ANTA(400KV)-KALISINDH (400KV)1	DAILY	FOR Halfyearly Maintenance work (Tightning of Nuts & Bolts of Clamp, Fixures & Jumpers).	2019-09-30	09:00	2019-09-30	18:00	9	158
126	RRVPN	RRVPN	LINE	AKAL JAISALMER (400KV)-BARMER (400KV)	DAILY	Quarterly Maintenance work at Barmer end	2019-09-21	10:00	2019-09-21	18:00	8	159

127	RRVPN	RRVPN	LINE	BARMER (400KV)-RAJWEST (400KV)	DAILY	Quarterly Maintenance work	2019-09-26	10:00	2019-09-26	18:00	8	159
128	RRVPN	RRVPN	LINE	BARMER (400KV)-BHINMAL (400KV)I	DAILY	Quarterly Maintenance	2019-09-27	10:00	2019-09-27	18:00	8	-
129	RRVPN	RRVPN	LINE	BARMER (400KV)-BHINMAL (400KV)II	DAILY	Quarterly Maintenance	2019-09-28	10:00	2019-09-28	18:00	8	-
130	RRVPN	RRVPN	LINE	BHADLA (400KV)-BikanerI	DAILY	Quarterly Maintenance work	2019-09-11	17:00	2019-09-11	21:00	4	-
131	RRVPN	RRVPN	LINE	BIKANER (400KV)-BHADLA (400KV)2	DAILY	Quarterly Maintenance work	2019-09-13	17:00	2019-09-13	21:00	4	161
132	RRVPN	RRVPN	LINE	AGRA-PG (220KV)-SIKANDRA (220KV)	DAILY	For line maintenance and tree cutting	2019-09-20	09:00	2019-09-20	18:00	9	160
133	RRVPN	RRVPN	LINE	BHARATPUR (220KV)-SIKANDRA (220KV)	CONTINUOUS	for maintenance of line and bay and replacement of earthwire 220KV GSS RVPN, Bharatpur and tree cutting continuous basis.	2019-09-23	09:00	2019-09-28	18:00	129	160
134	RRVPN	RRVPN	LINE	LALSOT (220KV)-DAUSA (220KV)PG	DAILY	Half yearly maintenance work	2019-09-03	09:30	2019-09-03	16:00	6.5	159
135	RRVPN	RRVPN	LINE	SAWAI MADHOPUR (220KV)-DAUSA (220KV)I(PG	DAILY	Half yearly maintenance work	2019-09-04	09:30	2019-09-04	16:00	6.5	159
136	RRVPN	POWERGRID	LINE	BASSI (220KV)-DAUSA (220KV)1	DAILY	Half yearly maintenance work	2019-09-05	09:30	2019-09-05	16:00	6.5	158
137	RRVPN	POWERGRID	LINE	BASSI (220KV)-DAUSA (220KV)2	DAILY	Half yearly maintenance work	2019-09-06	09:30	2019-09-06	16:00	6.5	160
138	RRVPN	POWERGRID	LINE	ANTA GPS (220KV)-LALSOT (220KV)(PG)	DAILY	Half yearly maintenance work	2019-09-03	09:30	2019-09-03	16:00	6.5	158
139	RRVPN	RRVPN	LINE	BHILWARA (400KV)-CHITTORGARH (400KV)II	DAILY	Half Yearly Maintenane of 400 KV CHITTOR-BHILWARA CKT-2 LINE&BAY(4152B)& ASSOCIATED EQUIPMENTS at 400kV GSS Bhilwara	2019-09-24	09:00	2019-09-24	17:00	8	158
140	RRVPN	RRVUNL	LINE	BHILWARA (400KV)-AJMER (400KV)I	DAILY	Half Yearly Maintenane of 400 KV AJMER-BHILWARA CKT-1 LINE&BAY(4352B)& ASSOCIATED EQUIPMENTS	2019-09-25	09:00	2019-09-25	17:00	8	160
141	RRVPN	RRVPN	LINE	BHILWARA (400KV)-AJMER (400KV)II	DAILY	Half Yearly maintenane of 400 KV AJMER-BHILWARA CKT-2 LINE&BAY(4452B)& ASSOCIATED EQUIPMENTS	2019-09-26	09:00	2019-09-26	17:00	8	160

142	RRVPN	APL	LINE	BIKANER (400KV)-DEEDWANA (400KV)	DAILY	Routine Bay Maintenance Work	2019-09-20	10:00	2019-09-20	13:00	3	161
143	RRVPN	POWERGRID	LINE	BASSI (400KV)-HEERAPURA (400KV)I	DAILY	3rd Quaterly maintenance of 400 KV side bay Equipments	2019-09-04	10:00	2019-09-04	17:00	7	161
144	RRVPN	POWERGRID	LINE	BASSI (400KV)-HEERAPURA (400KV)II	DAILY	3rd Quaterly maintenance of 400 KV side bay Equipments	2019-09-03	10:00	2019-09-03	17:00	7	161
145	RRVPN	RRVPN	LINE	HINDAUN (400KV)-HEERAPURA (400KV)	DAILY	3rd Quaterly maintenance of 400 KV side bay Equipments at both ends & 3rd Quaterly maintenance of 400 KV 50 MVAR Shunt reactor at Heerapura	2019-09-05	10:00	2019-09-06	17:00	14	161
146	RRVPN	RRVPN	LINE	PHAGI(400KV)-HEERAPURA (400KV)II	DAILY	3rd Quaterly maintenance of 400 KV side bay Equipments	2019-09-11	10:00	2019-09-11	17:00	7	161
147	RRVPN	RRVPN	LINE	MERTA (400KV)-HEERAPURA (400KV)	DAILY	3rd Quaterly maintenance of 400 KV side bay Equipments	2019-09-12	10:00	2019-09-12	17:00	7	160
148	RRVPN	RRVPN	LINE	PHAGI(400KV)-HEERAPURA (400KV)I	DAILY	3rd Quaterly maintenance of 400 KV side bay Equipments	2019-09-16	10:00	2019-09-16	17:00	7	161
149	RRVPN	RRVPN	LINE	HINDAUN (400KV)-CHHABRA (400KV)	DAILY	Quaterly & Half yearly Maintance	2019-09-20	09:00	2019-09-20	16:00	7	159
150	RRVPN	RRVPN	LINE	JODHPUR (400KV)-AKAL JAISALMER (400KV)	DAILY	3rd Quarterly maintenance work	2019-09-26	09:00	2019-09-26	17:00	8	159
151	RRVPN	RRVPN	LINE	Kankani 400 KV-MERTA (400KV)	DAILY	Quarterly Maintenance Work	2019-09-07	09:00	2019-09-07	18:00	9	160
152	RRVPN	POWERGRID	LINE	KOTA (400KV)-MERTA (400KV)I	DAILY	II-QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	2019-09-19	10:00	2019-09-19	17:00	7	160
153	RRVPN	RRVPN	LINE	AKAL JAISALMER (400KV)-RAMGARHI	DAILY	Half yearly Maintenance at Ramgarh	2019-09-05	10:00	2019-09-05	17:00	7	160
154	RRVPN	POWERGRID	LINE	SIKAR (400KV)-RATANGARH (400KV)1	DAILY	Maintenance work of bay equipments	2019-09-19	09:30	2019-09-19	18:00	8.5	160
155	RRVPN	POWERGRID	LINE	SIKAR (400KV)-RATANGARH (400KV)2	DAILY	Maintenance work of bay equipments	2019-09-20	09:30	2019-09-20	18:00	8.5	160
156	RRVPN	RRVPN	LINE	DEBARI (220KV)-RAPP A (220KV)	DAILY	Line Petrolling & General Maintenanace Work	2019-09-12	08:00	2019-09-12	17:00	9	159
157	RRVPN	POWERGRID	LINE	RAPS B (220KV)-DEBARI (220KV)	DAILY	General Maintenanace Work	2019-09-13	08:00	2019-09-13	17:00	9	159

158	RRVPN	RRVPN	LINE	AKAL JAISALMER (400KV)-Kankani 400 KVI	DAILY	Quarterly Maintenance Work	2019-09-21	09:00	2019-09-21	18:00	9	158
159	RRVPN	RRVPN	LINE	AKAL JAISALMER (400KV)-Kankani 400 KVII	DAILY	Quarterly Maintenance Work	2019-09-28	09:00	2019-09-28	18:00	9	158
160	RRVPN	RRVPN	LINE	Kankani 400 KV-JODHPUR (400KV)	DAILY	Quarterly Maintenance Work	2019-09-20	09:00	2019-09-20	18:00	9	159
161	RRVPN	APL	LINE	BIKANER (400KV)-Suratgarh (Super-critical)1	DAILY	Routine Bay Maintenance Work	2019-09-13	10:00	2019-09-13	13:00	3	-
162	RRVPN	APL	LINE	BIKANER (400KV)-Suratgarh (Super-critical)2	DAILY	Routine Bay Maintenance Work	2019-09-19	10:00	2019-09-19	13:00	3	-
163	RRVPN	POWERGRID	LINE	KANKROLI (400KV)-JODHPUR (400KV)	DAILY	3rd Quarterly maintenance work of Bay of 400kV Jodhpur - Kankroli (PG) at Jodhpur end.	2019-09-13	09:00	2019-09-13	17:00	8	161
164	RRVPN	RRVPN	LINE	BHADLA (400KV)-JODHPUR (400KV)	DAILY	For stringing of OPGW at diamond crossing of 132 KV Jodhpur-Bhawad line & LILO line of 400 Jodhpur-Merta at 400 KV GSS Bhadala	2019-09-09	18:30	2019-09-09	20:30	2	161
165	RRVPN	RRVPN	LINE	BHADLA (400KV)-MERTA (400KV)	DAILY	For stringing of OPGW at diamond crossing of 132 KV Jodhpur-Bhawad line & LILO line of 400 Jodhpur-Merta at 400 KV GSS Bhadala	2019-09-09	18:30	2019-09-09	20:30	2	160
166	RRVPN	POWERGRID	LINE	SIKAR (400KV)-BABAI GSS	DAILY	Quarterly Maintenance at Babai end	2019-09-24	07:00	2019-09-24	13:00	6	160
167	RRVPN	POWERGRID	LINE	BABAI GSS-NEEMRANA (400KV)	DAILY	Quarterly Maintenance at Babai	2019-09-26	07:00	2019-09-26	13:00	6	-
168	NRSS-XXIX	NRSS-XXIX	LINE	SAMBA (400KV)-AMARGARH (400KV)I	DAILY	A/R in non Auto mode, for the installation of OPGW in place of earth wire.	2019-09-01	07:30	2019-09-30	19:30	360	161
169	NRSS-XXIX	NRSS-XXIX	LINE	SAMBA (400KV)-AMARGARH (400KV)II	DAILY	A/R in non Auto mode, for the installation of OPGW in place of earth wire.	2019-09-01	07:30	2019-09-30	19:30	360	161
170	UPPTCL	UPPTCL	LINE	LUCKNOW (Sarojini Nagar) 400-UP-UNNAO (400KV)	DAILY	For Jumper Tightening And Other associated Works.	2019-09-12	09:00	2019-09-13	17:00	16	161
171	UPPTCL	POWERGRID	LINE	SINGRAULI NTPC (400KV)-LUCKNOW (Sarojini Nagar) 400-UP	DAILY	For routine T&C Testing and Bay Maintenance Works.	2019-09-03	08:00	2019-09-03	17:00	9	161
172	UPPTCL	UPPTCL	LINE	SHERKOT-KALAGARHSC	DAILY	For Lopping-Chopping of tree branches & other line maintenance work.	2019-09-12	10:00	2019-09-13	17:00	14	161
173	UPPTCL	UPPTCL	LINE	BAREILY-CB GANJ (220KV)-PANTNAGAR (220KV)	CONTINUOUS	For replacement of old & obsolete CT & CVT of Class 1.0ps	2019-09-08	08:00	2019-09-08	18:00	10	158

174	UPPTCL	UPPTCL	LINE	OBRA (400KV)-SULTANPUR (400KV)	DAILY	for routine bay maintenance works and CT replacement	2019-09-19	10:00	2019-09-19	18:00	8	161
175	UPPTCL	UPPTCL	LINE	LUCKNOW-Kursi Road (400KV) PG-SULTANPUR (400KV)	DAILY	for routine bay maintenance works	2019-09-16	10:00	2019-09-16	18:00	8	161
176	UPPTCL	UPPTCL	LINE	UNCHAHAR (220KV)-RAEBAREILLY (220KV)2	DAILY	For Lopping, Chopping and corridor clearance	2019-09-04	09:00	2019-09-05	17:00	16	158
177	UPPTCL	UPPTCL	LINE	UNCHAHAR (220KV)-RAEBAREILLY (220KV)2	DAILY	For Lopping Chopping and corridor clearance	2019-09-06	09:00	2019-09-07	17:00	16	158
178	UPPTCL	UPPTCL	LINE	SULTANPUR (400KV)-TANDA	DAILY	for routine bay maintenance works	2019-09-23	10:00	2019-09-23	18:00	8	158
179	UPPTCL	UPPTCL	LINE	AZAMGARH (400KV)-TANDA	DAILY	for divertion work of UPIEDA Purwanchal Express way	2019-09-05	08:00	2019-09-12	18:00	80	-
180	UPPTCL	UPPTCL	LINE	MURADNAGAR (400KV)-ALIGARH (400KV)	DAILY	For Looping-Chopping of Trees & Nest Removing	2019-09-04	08:00	2019-09-04	18:00	10	159
181	UPPTCL	UPPTCL	LINE	GREATER NOIDA(765 KV)-GREATER NOIDA (400KV)I	CONTINUOUS	For triming of trees under the line	2019-09-21	10:00	2019-09-21	17:00	7	-
182	UPPTCL	UPPTCL	LINE	NAPP (220KV)-KHURJA (220KV)1	DAILY	For replacement of DISC Insulator with polymer Insulator	2019-09-02	09:00	2019-09-04	18:00	27	157
183	UPPTCL	UPPTCL	LINE	NAPP (220KV)-KHURJA (220KV)2	DAILY	For replacement of DISC Insulator with polymer Insulator	2019-09-05	09:00	2019-09-07	18:00	27	155
184	UPPTCL	PTCUL	LINE	AFZALGARH-KALAGARH	DAILY	For Lopping-Chopping of tree branches & other line maintenance work.	2019-09-12	10:00	2019-09-13	17:00	14	161
185	UPPTCL	UPPTCL	LINE	NAPP (220KV)-SAMBHAL (220KV)	DAILY	Lopping, chopping and cutting of trees & line maintenance work.	2019-09-26	08:00	2019-09-27	17:00	18	161
186	UPPTCL	UPPTCL	LINE	ataur (ghaziabad)-MUZZAFARNAGAR-UP (400KV)	DAILY	Lopping chopping of trees and tightning of jumpers	2019-09-09	08:00	2019-09-11	17:00	27	158
187	UPPTCL	UPPTCL	LINE	AGRA-UP (400KV)-UNNAO (400KV)	DAILY	Jumper Tightening and Fixing of Pilot Strings	2019-09-04	08:00	2019-09-15	18:00	120	161
188	UPPTCL	UPPTCL	LINE	LALITPUR-TPS (765KV)-FATEHBAD_AGRA(765KV)II	DAILY	Regular Maintenance of line as per thermovision report (Jumper bolts and CC ring bolts tightening.)	2019-09-07	08:00	2019-09-09	18:00	30	161
189	UPPTCL	UPPTCL	LINE	FATEHBAD_AGRA(765KV)-MATHURA (400KV)I	DAILY	Jumper Tightening	2019-09-18	08:00	2019-09-20	19:00	33	155

190	UPPTCL	UPPTCL	LINE	FATEHBAD_AGRA(765KV)-AGRA SOUTHII	DAILY	Jumper Tightening	2019-09-17	09:00	2019-09-19	19:00	30	-
191	UPPTCL	UPPTCL	LINE	ORAI (400KV)-BANDA (400KV)1	DAILY	For routine maintenance and testing of Bay	2019-09-04	10:00	2019-09-04	19:00	9	161
192	UPPTCL	UPPTCL	LINE	ORAI (400KV)-MAINPURI-UP (765KV)2	DAILY	For routine maintenance and testing of Bay	2019-09-06	10:00	2019-09-06	19:00	9	161
193	UPPTCL	UPPTCL	LINE	SAHUPURI (132KV)-KARMNASA BSEB-ER (132KV)	CONTINUOUS	Maintenance work	2019-09-14	10:00	2019-09-14	13:00	3	161
194	UPPTCL	UPPTCL	LINE	AZAMGARH (400KV)-SARNATH (400KV)	CONTINUOUS	Diversion of 400 KV Sarnath- Azamgarh line for UPEIDA	2019-09-16	08:00	2019-09-24	18:00	202	158
195	UPPTCL	POWERGRID	LINE	ANPARA-B (400KV)-SARNATH (400KV)1	CONTINUOUS	Diversion of 400 KV Anpara -Sarnath L-3 line for the proposed DFCC corridor	2019-09-20	08:00	2019-09-28	18:00	202	161
196	UPPTCL	UPPTCL	LINE	ANPARA-B (400KV)-OBRA (400KV)	CONTINUOUS	Diversion of 400 KV Obra- Anpara L-2 line for the proposed coal handling area of 2x600 MW	2019-09-02	08:00	2019-09-14	18:00	298	161
197	UPPTCL	UPPTCL	LINE	ANPARA-B (400KV)-MAU (400KV)	DAILY	For tightening of complete bay, maintenance and relay retrofitting	2019-09-23	09:00	2019-09-23	18:00	9	161
198	UPPTCL	UPPTCL	LINE	HAPUR-ataur (ghaziabad)I	DAILY	Replenishment of tower parts, jumper bolts, cc rings and tree trimming.	2019-09-04	09:00	2019-09-04	13:00	4	154
199	UPPTCL	UPPTCL	LINE	HAPUR-ataur (ghaziabad)II	DAILY	Replenishment of tower parts, jumper bolts, cc rings and tree trimming.	2019-09-04	14:00	2019-09-04	18:00	4	154
200	UPPTCL	UPPTCL	LINE	SAHUPURI (220KV)-PUSAULI BSEB-ER (220KV)+BSEB	CONTINUOUS	Maintenance work	2019-09-12	11:00	2019-09-12	15:00	4	161
201	UPPTCL	UPPTCL	LINE	CHANDOLI (132KV)-KARMNASA BSEB-ER (132KV)+MPSE	CONTINUOUS	Maintenance work	2019-09-13	10:00	2019-09-13	13:00	3	161
202	DTL	DTL	BAY	CB 1752 OF 400kV BAMNAULI-JHATIKARA CKT-I(BUS-I) AT BAMNAULI	CONTINUOUS	For Replacement of BHEL CB with AREVA CB by OEM M/s GE T&D India Ltd.	2019-09-23	06:00	2019-10-01	17:30	203.5	-
203	DTL	DTL	BAY	400kV CB42052 CONTROLLING ICT-1 AT BAWANA	DAILY	Testing of Breaker Timing &DCRM, bay Maintenance as PMS schedule of DTL.	2019-09-13	10:00	2019-09-13	16:00	6	155
204	DTL	DTL	BAY	400kV CB 42152 CONTROLLING 315MVA ICT-1 & 315MVA ICT-4 AT BAWANA	DAILY	Testing of Breaker Timing &DCRM, bay Maintenance as PMS schedule of DTL.	2019-09-16	10:00	2019-09-16	16:00	6	155
205	DTL	DTL	BAY	400kV CB 42252 CONTROLLING 315MVA ICT-4 (BUS-II) AT BAWANA	DAILY	Testing of Breaker Timing &DCRM, bay Maintenance as PMS schedule of DTL.	2019-09-17	10:00	2019-09-17	16:00	6	155

206	DTL	DTL	BAY	400kV CB No-42452 CONTROLLING 315MVA ICT-V (BUS-I) AT BAWANA	DAILY	Testing of Breaker Timing &DCRM, bay Maintenance as PMS schedule of DTL.	2019-09-18	10:00	2019-09-18	16:00	6	-
207	DTL	DTL	BAY	400kV CB 42552 CONTROLLING 315MVA ICT-5 & 315MVA ICT-6 AT BAWANA	DAILY	Testing of Breaker Timing &DCRM, bay Maintenance as PMS schedule of DTL.	2019-09-19	10:00	2019-09-19	16:00	6	155
208	DTL	DTL	BAY	400kB CB No-42652 CONTRLLING 315MVA ICT-VI (BUS-II) AT BAWANA	DAILY	Testing of Breaker Timing &DCRM, bay Maintenance as PMS schedule of DTL.	2019-09-20	10:00	2019-09-20	16:00	6	-
209	DTL	DTL	BAY	BAY NO 40152 (MAIN CB WITH BUS-I)OF MUNDKA-JHATIKARANA-1	DAILY	Testing of Breakers (Timing & CRM), Bay Maintenance as per PMS sechedule of DTL.	2019-09-02	10:00	2019-09-02	13:00	3	150
210	DTL	DTL	BAY	BAY NO 40252 (MAIN CB WITH BUS-2) FOR MUNDKA - JHATIKALAN-I	DAILY	Testing of Breakers (Timing & CRM), Bay Maintenance as per PMS sechedule of DTL.	2019-09-02	14:00	2019-09-02	17:00	3	150
211	DTL	DTL	BAY	BAY NO 40352 (MAIN CB WITH BUS-1) FOR MUNDKA - JHATIKALAN-II	DAILY	Testing of Breakers (Timing & CRM), Bay Maintenance as per PMS schedule of DTL.	2019-09-03	10:00	2019-09-03	13:00	3	150
212	DTL	DTL	BAY	BAY NO 40452 (MAIN CB WITH BUS-2) FOR MUNDKA- JHATIKALAN-II	DAILY	Testing of Breakers (Timing & CRM), Bay Maintenance as per PMS schedule of DTL.	2019-09-03	14:00	2019-09-03	17:00	3	150
213	DTL	DTL	BAY	BAY NO 40952 (TIE CB) FOR 315MVA ICT-2	DAILY	Testing of Breakers (Timing & CRM), Bay Maintenance as per PMS schedule of DTL.	2019-09-04	10:00	2019-09-04	13:00	3	150
214	DTL	DTL	BAY	BAY NO 41052 (MAIN CB) FOR 315MVA ICT-2	DAILY	Testing of Breakers (Timing & CRM), Bay Maintenance as per PMS schedule of DTL.	2019-09-04	14:00	2019-09-04	17:00	3	150
215	DTL	DTL	BAY	BAY NO 41152 (MAIN CB WITH BUS-1) FOR MUNDKA - JHAJJAR-2	DAILY	Testing of Breakers (Timing & CRM), Bay Maintenance as per PMS schedule of DTL.	2019-09-05	10:00	2019-09-05	13:00	3	150
216	DTL	DTL	BAY	BAY NO 41452 (MAIN CB WITH BUS-1) FOR MUNDKA - JHAJJAR-1	DAILY	Testing of Breakers (Timing & CRM), Bay Maintenance as per PMS schedule of DTL.	2019-09-05	14:00	2019-09-05	17:00	3	150
217	DTL	DTL	BAY	BAY NO 41252 (TIE CB) FOR 315MVA ICT-3	DAILY	Testing of Transformer (C& Tan Delta & other tests as per PMS schedule of DTL).	2019-09-07	10:00	2019-09-07	13:00	3	150
218	DTL	DTL	BAY	BAY NO 41352 (MAIN CB) FOR 315MVA ICT-3	DAILY	Testing of Transformer (C& Tan Delta & other tests as per PMS schedule of DTL).	2019-09-07	14:00	2019-09-07	17:00	3	150
219	DTL	DTL	BAY	BAY NO 41552 (TIE CB) FOR 315MVA ICT-4	DAILY	Testing of Transformer (C& Tan Delta & other tests as per PMS schedule of DTL).	2019-09-09	10:00	2019-09-09	13:00	3	150
220	DTL	DTL	BAY	BAY NO 41652 (MAIN CB) 315MVA ICT-4	DAILY	Testing of Transformer (C& Tan Delta & other tests as per PMS schedule of DTL).	2019-09-09	14:00	2019-09-09	17:00	3	150
221	DTL	DTL	BAY	BAY NO 41752 (MAIN CB WITH BUS-1) FOR MUNDKA - BAWANA -2	DAILY	Testing of Transformer (C& Tan Delta & other tests as per PMS schedule of DTL).	2019-09-11	10:00	2019-09-11	13:00	3	150

222	DTL	DTL	BAY	BAY NO 41852 (MAIN CB WITH BUS-2) FOR MUNDKA - BAWANA -2	DAILY	Testing of Transformer (C& Tan Delta & other tests as per PMS schedule of DTL).	2019-09-11	14:00	2019-09-11	17:00	3	150
223	DTL	DTL	BAY	BAY NO 41952 (MAIN CB WITH BUS-1) FOR MUNDKA - BAWANA -1	DAILY	Testing of Transformer (C& Tan Delta & other tests as per PMS schedule of DTL).	2019-09-12	10:00	2019-09-12	13:00	3	150
224	DTL	DTL	BAY	BAY NO 42052 (MAIN CB WITH BUS-2) FOR MUNDKA - BAWANA -1	DAILY	Testing of Transformer (C& Tan Delta & other tests as per PMS schedule of DTL).	2019-09-12	14:00	2019-09-12	17:00	3	150
225	DTL	DTL	BAY	CB No. 40652	DAILY	Testing of Transformer (C& Tan Delta & other tests as per PMS schedule of DTL).	2019-09-13	10:00	2019-09-13	13:00	3	-
226	DTL	DTL	BAY	CB NO 40752(SPARE BAY) AT MUNDKA	DAILY	Testing of Transformer (C& Tan Delta & other tests as per PMS schedule of DTL).	2019-09-13	14:00	2019-09-13	17:00	3	-
227	POWERGRID	POWERGRID	BAY	765KV G.NOIDA T/ BAY 714 AT MEERUT	DAILY	AMP WORK	2019-08-24	09:30	2019-08-25	18:30	18	151
228	POWERGRID	POWERGRID	BAY	765KV ICT-I T/ BAY 702 AT MEERUT	DAILY	Construction Work : Testing of 765 KV CB in Bay -701. S/d due to induction problem & 702 T/BAY is near to 701.	2019-08-27	09:00	2019-09-01	19:00	60	160
229	POWERGRID	POWERGRID	BAY	765KV ICT-4 M/BAY 718 AT JHATIKRA	DAILY	AMP work	2019-09-10	09:00	2019-09-11	18:00	18	154
230	POWERGRID	POWERGRID	BAY	765KV Chitorgarh-I M/bay 709 at ajmer	DAILY	CT oil sampling line remain in service through its tie bay during shutdown	2019-09-04	09:30	2019-09-04	10:30	1	-
231	POWERGRID	POWERGRID	BAY	765KV Bikaner-II M/bay 706 at ajmer	DAILY	AMP work	2019-09-12	09:00	2019-09-12	18:00	9	-
232	POWERGRID	POWERGRID	BAY	765KV Chitorgarh-I T/Bay 708 at Ajmer	DAILY	AMP work.	2019-09-13	09:00	2019-09-13	18:00	9	-
233	POWERGRID	POWERGRID	BAY	ALLAHABAD MAIN BAY , at Kanpur	CONTINUOUS	for isolator(40189A) retrofitment work under Add Cap. at 400kV Kanpur S/S	2019-09-02	09:00	2019-09-06	18:00	105	159
234	POWERGRID	POWERGRID	BAY	FATEHPUR-2 MAIN BAY, at Kanpur	CONTINUOUS	for isolator(40489A) retrofitment work under Add Cap. at 400kV Kanpur S/S	2019-09-16	09:00	2019-09-20	18:00	105	155
235	POWERGRID	POWERGRID	BAY	PANKI-2 MAIN BAY, at Kanpur	CONTINUOUS	for isolator(40689A) retrofitment work under Add Cap. at 400kV Kanpur S/S	2019-09-23	09:00	2019-09-27	18:00	105	148
236	POWERGRID	POWERGRID	BAY	710 Bay (Main bay of 765 KV Fatehpur Agra-2 Line), at Fatehpur	DAILY	AMP OF BAY EQUIPMENT at Agra end	2019-09-02	09:00	2019-09-03	18:00	18	160
237	POWERGRID	POWERGRID	BAY	765 KV ICT-1 Main Bay 703, at Agra HVDC	DAILY	SF6 Dew point mst & Rectification of IPS tube at Agra Substation.	2019-09-04	09:00	2019-09-04	13:00	4	161

238	POWERGRID	POWERGRID	BAY	(Tie bay of 765 kV ICT-2 -Future Line bay) ,at Bareily	DAILY	AMP WORK at 765kV Bareilly S/S	2019-09-06	09:00	2019-09-06	18:00	9	151
239	POWERGRID	POWERGRID	BAY	765kV Bareilly Line Tie Bay at Lucknow	DAILY	AMP WORK at 765kV Bareilly S/S	2019-09-07	09:00	2019-09-07	18:00	9	153
240	POWERGRID	POWERGRID	BAY	765 KV Tie Bay of Fatehpur-Agra Line-2 , at Fatehpur	DAILY	AMP & Tightening Work at Fatehpur end	2019-09-03	09:00	2019-09-04	18:00	18	150
241	POWERGRID	POWERGRID	BAY	706 Main Bay (ICT-II Main bay) , at Kanpur (GIS)	DAILY	FOR AMP work at Kanpur GIS S/S	2019-09-04	10:00	2019-09-04	18:00	8	150
242	POWERGRID	POWERGRID	BAY	707 Main Bay (ICT-I Main bay) , at Kanpur (GIS)	DAILY	FOR AMP work at Kanpur GIS S/S	2019-09-06	10:00	2019-09-06	10:00	0	150
243	POWERGRID	POWERGRID	BAY	711 Tie Bay (Bus Reactor-I & Aligarh Tie) at Kanpur	DAILY	FOR AMP work at Kanpur GIS S/S	2019-09-11	10:00	2019-09-11	06:00	-4	147
244	POWERGRID	POWERGRID	BAY	713 Main Bay (Bus Reactor-II Main Bay), at Kanpur	DAILY	FOR AMP work at Kanpur GIS S/S	2019-09-13	10:00	2019-09-13	18:00	8	150
245	POWERGRID	POWERGRID	BAY	714 Tie Bay (Bus Reactor-II & Future Tie) , at Kanpur	DAILY	FOR AMP work at Kanpur GIS S/S	2019-09-18	10:00	2019-09-18	18:00	8	147
246	POWERGRID	POWERGRID	BAY	712 ICT-2 main Bay at 765kV bareilly Sbubstation	DAILY	AMP WORK at 765kV Bareilly S/S	2019-09-05	09:30	2019-09-05	18:30	9	-
247	POWERGRID	POWERGRID	BAY	715 Main Bay (Future Bay) ,at Kanpur	DAILY	FOR AMP work at Kanpur GIS S/S	2019-09-20	09:30	2019-09-20	18:30	9	150
248	POWERGRID	POWERGRID	BAY	765KV MEERUT M/BAY 707 AT BHIWANI	DAILY	For AMP Work	2019-09-04	08:00	2019-09-05	18:00	20	151
249	POWERGRID	POWERGRID	BAY	765 KV JHATIKRA M/BAY 710 AT BHIWANI	DAILY	For AMP Work	2019-09-19	09:00	2019-09-20	18:00	18	151
250	POWERGRID	POWERGRID	BAY	765KV ICT-II M/ BAY 709 AT BHIWANI	DAILY	For AMP Work	2019-09-11	08:00	2019-09-12	18:00	20	151
251	POWERGRID	POWERGRID	BAY	765KV MEERUT/ICT-II TIE BAY 708 AT BHIWANI	DAILY	For AMP Work	2019-09-09	09:00	2019-09-10	10:00	2	151
252	POWERGRID	POWERGRID	BAY	765KV PHAGI-1 M/BAY 716 BHIWANI	CONTINUOUS	For Attending SF6 leakage by removal of Interruptor of R Phase SD is being clubbed with Phagi-Bhiwani I Line SD as the Line SD is also required considering safe working area of Crane.	2019-09-16	09:30	2019-09-17	18:30	33	146
253	POWERGRID	POWERGRID	BAY	765 KV JHATIKRA /ICT-1T/BAY 711 AT BHIWANI	DAILY	For AMP Work	2019-09-19	09:00	2019-09-20	18:00	18	153

254	POWERGRID	POWERGRID	BAY	765 KV ICT-1 M/BAY 712 AT BHIWANI	DAILY	For AMP Work	2019-09-23	09:00	2019-09-24	18:00	18	153
255	POWERGRID	POWERGRID	BAY	708- 765kV Bus Reactor Tie Bay , at Lucknow	DAILY	For AMP Work at Lucknow S/S	2019-09-02	09:00	2019-09-03	18:00	18	159
256	POWERGRID	POWERGRID	BAY	765kV Bareilly Line Main Bay, at Bareily	DAILY	For AMP Work at Lucknow S/S	2019-09-04	09:00	2019-09-05	18:00	18	155
257	POWERGRID	POWERGRID	BAY	701R-240Mvar Balia Line Reactor Bay	DAILY	For AMP work at Lucknow S/S.	2019-09-12	09:30	2019-09-13	18:30	18	-
258	POWERGRID	POWERGRID	BAY	220KV Bus coupler Bay 206 at Bassi	CONTINUOUS	TELK Make 245 C.B. replacement work with Seimens Make C.B. .During Replacement work Line/ICT will charge through Transfer bus coupler.	2019-09-01	09:30	2019-09-06	18:30	129	-
259	POWERGRID	POWERGRID	BAY	220KV Dausa-I Bay 208 at bassi	CONTINUOUS	TELK Make 245 C.B. replacement work with Seimens Make C.B. .During Replacement work Line/ICT will charge through Transfer bus coupler.	2019-09-07	09:00	2019-09-12	18:00	129	-
260	POWERGRID	POWERGRID	BAY	400kv Hapur line m/bay 492 at Muradnagr	CONTINUOUS	Shutdown for 400 KV ABB CB Overhauling	2019-09-24	09:30	2019-10-02	18:30	201	160
261	POWERGRID	POWERGRID	BAY	400KV ICT-3 T/bay 406 at Bawana SS	CONTINUOUS	For BHEL CB retrofit with Siemens	2019-09-02	09:00	2019-09-10	18:00	201	160
262	POWERGRID	POWERGRID	BAY	400KV ICT-2 M/BAY 412 MANDOLA	CONTINUOUS	For isolator retrofitment job under ADD CAP	2019-09-03	09:00	2019-09-08	18:00	129	156
263	POWERGRID	POWERGRID	BAY	400KV ICT-2 T/BAY 411 MANDOLA	CONTINUOUS	For isolator retrofitment job under ADD CAP	2019-09-08	09:00	2019-09-14	18:00	153	150
264	POWERGRID	POWERGRID	BAY	400KV ICT-1 M/BAY 415 MANDOLA	CONTINUOUS	For isolator retrofitment job under ADD CAP	2019-09-15	09:00	2019-09-20	18:00	129	157
265	POWERGRID	POWERGRID	BAY	400KV Meerut-II & Dadri-I T/bay 420 at mandola	CONTINUOUS	For isolator retrofitment job under ADD CAP	2019-09-22	10:00	2019-09-27	17:00	127	159
266	POWERGRID	POWERGRID	BAY	220KV Dausa-2 Bay 209 at bassi	CONTINUOUS	TELK Make 245 C.B. replacement work with Seimens Make C.B. .During Replacement work Line/ICT will charge through Transfer bus coupler.	2019-09-13	09:30	2019-09-18	18:30	129	-
267	POWERGRID	POWERGRID	BAY	220KV IG Ngar Bay no-213 at Bassi	CONTINUOUS	TELK Make 245 C.B. replacement work with Seimens Make C.B. .During Replacement work Line/ICT will charge through Transfer bus coupler.	2019-09-19	09:00	2019-09-24	18:00	129	-
268	POWERGRID	POWERGRID	BAY	400KV Future bay 405 at Bawana	CONTINUOUS	For BHEL CB retrofit with Siemens	2019-08-22	09:00	2019-08-30	18:00	201	-

269	POWERGRID	POWERGRID	BAY	400KV ICT-III M/Bay 407 at Bawana	CONTINUOUS	For BHEL CB retrofit with Siemens	2019-09-12	21:55	2019-09-20	21:55	192	-
270	POWERGRID	POWERGRID	BAY	400KV Bhiwani(BBMB) M/bay-410 at Hisar	CONTINUOUS	Retrofitment of Old Circuit Breaker with new Circuit Breakers	2019-08-20	09:30	2019-08-28	18:30	201	-
271	POWERGRID	POWERGRID	BAY	400KV ICT-II M/bay-406 at Hisar	CONTINUOUS	Retrofitment of Old Circuit Breaker with new Circuit Breakers	2019-08-29	09:00	2019-09-06	18:00	201	-
272	POWERGRID	POWERGRID	BAY	400KV Kaithal -I & ICT-II T/bay-405 at Hisar	CONTINUOUS	Retrofitment of Old Circuit Breaker with new Circuit Breakers	2019-09-07	09:00	2019-09-14	18:00	177	-
273	POWERGRID	POWERGRID	BAY	400KV Bhiwadi-I M/bay 413 at Hisar	CONTINUOUS	Retrofitment of Old Circuit Breaker with new Circuit Breakers	2019-09-15	09:00	2019-09-21	18:00	153	-
274	POWERGRID	POWERGRID	BAY	400KV Kaithal-I M/bay 404 at Hisar	CONTINUOUS	Retrofitment of Old Circuit Breaker with new Circuit Breakers	2019-09-22	09:00	2019-09-28	18:00	153	-
275	POWERGRID	POWERGRID	BAY	400KV Kaithal-II M/bay 409 at Hisar	CONTINUOUS	Retrofitment of Old Circuit Breaker with new Circuit Breakers	2019-09-29	09:00	2019-10-05	18:00	153	-
276	POWERGRID	POWERGRID	BAY	Panki-1, Main Bay, at Kanpur	CONTINUOUS	For isolator(40389A) retrofitment work under Add Cap. at 400kV Kanpur S/S	2019-09-09	09:30	2019-09-13	18:30	105	-
277	POWERGRID	POWERGRID	BAY	412-400kV Kanpur Line- 1 Main Bay , at Lucknow	DAILY	For AMP Work at 765/400kV Lucknow S/S	2019-09-20	09:30	2019-09-20	18:30	9	-
278	POWERGRID	POWERGRID	BAY	Kanpur Line-2 Main Bay , at Lucknow	DAILY	For AMP Work at 765/400kV lucknow S/S	2019-09-21	09:30	2019-09-21	18:30	9	-
279	RRVPN	RRVPN	BAY	800kV CB (705-52T) for 765kV 3*80MVAR Bus reactor at 765kV GSS Phagi	DAILY	1. To check the operation timings of CB & measurement of contact resistance.. 2. Measurement of Tan-delta of CTs. 3.Tightening of clamps & connectors.	2019-09-12	09:00	2019-09-12	18:00	9	156
280	RRVPN	RRVPN	BAY	800kV CB (702-52A) for 765kV Phagi-Bhiwani-I line at 765kV GSS Phagi	DAILY	1. Maintenance of CB & Reactors. 2. Maintenance of line bay equipments	2019-09-17	09:00	2019-09-18	18:00	18	150
281	RRVPN	RRVPN	BAY	800kV 702-52B CB of ICT-2 at 7656kV GSS Phagi	DAILY	1.Maintenance of CB 2. Measurement of IR & Tan-delta of CTs. 3.Tightning of clamp & connectors	2019-09-25	09:00	2019-09-25	18:00	9	154
282	RRVPN	RRVPN	BAY	410-52C CB for 400kV ICT-2 at 765KV GSS Phagi	DAILY	1.For the tightening of clamps & connectors of CTs, CB & isolators. 2. For the measurement of Tan-delta of CTs.	2019-09-04	09:00	2019-09-04	18:00	9	149
283	RRVPN	ADANIRJ	BAY	Bay 401(Bus Reactor-1 Main Bay) at 400kV GSS Kawai	DAILY	Annual Maintenance of Bus Reactor 1 & connected isolators & LA	2019-09-06	09:30	2019-09-06	19:30	10	160
284	RRVPN	ADANIRJ	BAY	Tie Bay 402 Bus Reactor -1 and Kawai Anta Line - 1	DAILY	Annual Maintenance of Bus Reactor 1 & connected isolators & LA	2019-09-06	09:30	2019-09-06	19:30	10	160

285	RRVPN	RRVPN	BAY	4152T tie bay for ICT-1 AT 400KV GSS BHILWARA	DAILY	Half Yearly maintenance of 400 KV Tie-1 BAY(4152T)& ASSOCIATED EQUIPMENTS	2019-09-03	09:00	2019-09-03	18:00	9	158
286	RRVPN	RRVPN	BAY	4252T tie bay for ICT-2 AT 400KV GSS BHILWARA	DAILY	Half Yearly maintenance of 400 KV Tie-2 BAY(4252T)& ASSOCIATED EQUIPMENTS	2019-09-04	09:00	2019-09-04	17:00	8	153
287	RRVPN	RRVPN	BAY	4352T tie bay for 400kv Chhabra-Bhilwara line AT BHILWARA	DAILY	Half Yearly maintenance of 400 KV Tie-3 BAY(4352T)& ASSOCIATED EQUIPMENTS	2019-09-05	09:00	2019-09-05	17:00	8	159
288	RRVPN	RRVPN	BAY	4452T tie bay for 400kV Ajmer-Bhilwara-II AT BHILWARA	DAILY	Half Yearly maintenance of 400 KV Tie-4 BAY(4452T)& ASSOCIATED EQUIPMENTS	2019-09-06	09:00	2019-09-06	17:00	8	159
289	RRVPN	RRVPN	BAY	6052T Tie bay of PGCIL-II at 400kV GSS Chittorgarh	DAILY	FOR MAINTAINCE WORK	2019-09-18	09:00	2019-09-20	17:00	24	155
290	RRVPN	RRVPN	BAY	552T Tie CB for Ramgarh-Akal-I	DAILY	Half yearly Maintenance	2019-09-11	10:00	2019-09-11	17:00	7	160
291	RRVPN	RRVPN	BAY	400kV 552-A CB of 400kV Ramgarh-Akal-I (Presently known as Ramgarh-bhadla-I)	DAILY	Half yearly Maintenance	2019-09-11	10:00	2019-09-11	17:00	7	160
292	UPPTCL	UPPTCL	BAY	400 kV Kanpur(PGCIL)-II at 400 kV Panki(UPPTCL)	DAILY	Routine testing & bay maintenance.	2019-09-19	08:00	2019-09-20	17:00	18	-
293	UPPTCL	UPPTCL	BAY	400KV Sarnath-Anpara B (L5) LIne BAY	CONTINUOUS	Replacement of old & outlived 0.5 accuracy CT by new 0.2 accuracy CT alongwith strengthening of 400 KV Main Bus - II & Transfer Bus and complete overhauling of Isolators	2019-09-18	08:00	2019-09-19	18:00	34	-
294	UPPTCL	UPPTCL	BAY	400 KV Sarnath-Varanasi - I (PGCIL) Line BAY	CONTINUOUS	Replacement of old & outlived 0.5 accuracy CT by new 0.2 accuracy CT alongwith strengthening of 400 KV Main Bus - II & Transfer Bus and complete overhauling of Isolators	2019-09-20	08:00	2019-09-21	18:00	34	-
295	UPPTCL	UPPTCL	BAY	400 KV Bus Coupler BAY at Sarnath	CONTINUOUS	Replacement of old & outlived 0.5 accuracy CT by new 0.2 accuracy CT of 400 KV Bus Coupler Bay	2019-09-18	08:00	2019-09-23	18:00	130	-
296	HVPNL	HVPNL	BUS	BUS I DHANODA	DAILY	For general mtc of isolators and attending the hot spots.	2019-09-10	08:00	2019-09-10	14:00	6	-
297	HVPNL	HVPNL	BUS	400kv bus-2 dhanonda	DAILY	For general mtc. of isolators and attending hot spots	2019-09-12	08:00	2019-09-12	14:00	6	145
298	HVPNL	HVPNL	BUS	BUS-1	DAILY	Annual Maintenance & testing of BUS equipment at 400kV Kabulpur	2019-09-09	08:00	2019-09-09	16:00	8	-
299	HVPNL	HVPNL	BUS	BUS - 2	DAILY	Annual Maintenance & testing of BUS equipment at 400kV Kabulpur	2019-09-11	08:00	2019-09-11	16:00	8	-

300	HVPNL	HVPNL	BUS	400KV BUS-1 D/Bad	DAILY	Replacement of 1 No isolator 40289 B of Daultabad-Dhanonda ckt 1	2019-08-23	10:00	2019-08-23	17:00	7	160
301	NTPC	NTPC	BUS	NTPC RIHAND 400KV BUS - 4	CONTINUOUS	Rihand : 400 KV Bus-4 - for annual maintenance of bay equipments	2019-09-10	08:30	2019-09-10	18:30	10	156
302	NTPC	NTPC	BUS	NTPC RIHAND 400KV BUS - 5	CONTINUOUS	Rihand 400 KV Bus-5: for annual maintenance of bay equipment's	2019-09-13	08:30	2019-09-13	18:30	10	-
303	NTPC	NTPC	BUS	NTPC RIHAND 400KV BUS - 2	CONTINUOUS	Rihand 400 KV Bus-6: annual maintenance of bay equipments (code for Bus-6 not available, hence Bus-2 code selected).	2019-09-20	08:30	2019-09-20	18:30	10	-
304	NTPC	NTPC	BUS	SINGRAULI 400KV BUS - I	CONTINUOUS	400kV Bus coupler-1-: for 400kV Breaker and CT Replacement.)bus coupler code not available.	2019-09-14	08:30	2019-09-18	18:30	106	154
305	NTPC	NTPC	BUS	KOLDAM BUS 1	CONTINUOUS	Disc Insulator replacement R-Phase Ludhiana line Bay#13 in Koldam Switchyard	2019-09-17	09:30	2019-09-17	18:30	9	153
306	NTPC	NTPC	BUS	KOLDAM BUS 1	DAILY	Disc Insulator replacement B-Phase Ludhiana line Bay#13 in Koldam Switchyard	2019-09-19	09:00	2019-09-19	17:30	8.5	153
307	POWERGRID	POWERGRID	BUS	765KV BUS -I JHATIKRA	DAILY	AMP work + Counter weight installation	2019-09-17	09:00	2019-09-17	19:00	10	157
308	POWERGRID	POWERGRID	BUS	765 KV Bus-2, at Fatehpur	DAILY	AMP & Tightening Work at Fatehpur end	2019-09-06	09:00	2019-09-06	18:00	9	156
309	POWERGRID	POWERGRID	BUS	765KV BUS-I MEERUT	DAILY	Construction work:BUS-1 Jumpering Work of errection of NEW ICT-III at 765KV Meerut s/s	2019-09-17	09:00	2019-09-18	18:00	18	158
310	POWERGRID	POWERGRID	BUS	765KV BUS-II MEERUT	DAILY	Construction work:BUS-2 Jumpering Work of errection of NEW ICT-III at 765KV Meerut S/S	2019-09-19	09:00	2019-09-20	18:00	18	158
311	POWERGRID	POWERGRID	BUS	400 KV WCA Bus-1/1A sectionaliser, at Agra HVDC	DAILY	AMP of Bay Equipment i.e. CB , CT etc at HVDC Agra	2019-09-06	09:00	2019-09-06	18:00	9	-
312	POWERGRID	POWERGRID	BUS	400 KV WCA Bus-2/2A sectionaliser, at Agra HVDC	DAILY	AMP of Bay Equipment i.e. CB , CT etc at HVDC Agra	2019-09-07	09:00	2019-09-07	18:00	9	-
313	POWERGRID	POWERGRID	BUS	Bus-2B, at Agra	DAILY	Point to point testing of Bus Bar Protection M1 / M2, REB 500 at Agra HVDC	2019-09-09	09:00	2019-09-10	18:00	18	155
314	POWERGRID	POWERGRID	BUS	Bus 1A, at Agra	DAILY	Stablity test between new replaced CT and existing CT for correct summation in Bus Bar Prot. at HVDC Agra.	2019-09-14	13:00	2019-09-14	17:00	4	152
315	POWERGRID	POWERGRID	BUS	Bus 2A, at Agra HVDC	DAILY	Stablity test between new replaced CT and existing CT for correct summation in Bus Bar Prot. at HVDC Agra	2019-09-18	13:00	2019-09-19	17:00	8	145

316	POWERGRID	POWERGRID	BUS	400 KV WCA Bus-1/1A sectionaliser, at Agra HVDC	DAILY	Repalcement of Bus sectionaliser CT of three phases with 4000/1A CT under retrofitment of Bus bar Protection at HVDC Agra.	2019-09-12	09:00	2019-09-13	13:00	8	-
317	POWERGRID	POWERGRID	BUS	400 KV WCA Bus-2/2A sectionaliser, at Agra HVDC	DAILY	Repalcement of Bus sectionaliser CT of three phases with 4000/1A CT under retrofitment of Bus bar Protection at HVDC Agra	2019-09-16	09:00	2019-09-17	13:00	8	-
318	POWERGRID	POWERGRID	BUS	Bus-1B , at Agra	DAILY	Point to point testing of Bus Bar Protection M1 / M2, REB 500 at Agra HVDC,	2019-09-04	09:00	2019-09-05	18:00	18	155
319	POWERGRID	POWERGRID	BUS	400KV WCB Bus-1A/1B Sectionaliser, at Agra HVDC	DAILY	AMP of Bay Equipment i.e. CB , CT etc at HVDC Agra.	2019-09-02	09:00	2019-09-02	18:00	9	-
320	POWERGRID	POWERGRID	BUS	400KV WCB Bus-2A/2B Sectionaliser, at Agra HVD	DAILY	AMP of Bay Equipment i.e. CB , CT etc at HVDC Agra	2019-09-03	09:00	2019-09-03	18:00	9	-
321	POWERGRID	POWERGRID	BUS	220 KV BUS-1, at Lucknow	DAILY	AMP WORK of 220kv BUS-1 at 400kV lucknow S/S	2019-09-04	09:00	2019-09-04	18:00	9	155
322	POWERGRID	POWERGRID	BUS	Bus-2, at Lucknow	DAILY	AMP WORK of 220kV BUS-2 at 400kV lucknow S/S	2019-09-05	09:00	2019-09-05	18:00	9	158
323	POWERGRID	UPPTCL	BUS	400 kV Main bus 2 at Gorakhpur (UPPTCL)	DAILY	For hotspot rectification in 40289 A isolator at Gorakhpur Substation	2019-09-26	09:00	2019-09-26	18:00	9	161
324	POWERGRID	POWERGRID	BUS	765kV BUS-I at ALIGARH	CONTINUOUS	Interconnection of Existing Bus with New Bus at 765kV Aligarh S/S	2019-08-21	08:00	2019-08-23	18:00	58	-
325	POWERGRID	POWERGRID	BUS	765kV Bus-II at Aligarh	CONTINUOUS	For interconnection of Existing Bus with new Bus at 765kV Aligarh S/S	2019-08-24	08:00	2019-08-26	18:00	58	-
326	POWERGRID	POWERGRID	BUS	765kV BUS-I at ALIGARH	CONTINUOUS	HV and Impulse Testing of Extension of GIS at 765kV Aligarh S/S	2019-08-29	08:00	2019-08-31	18:00	58	-
327	POWERGRID	POWERGRID	BUS	765kV Bus-II at Aligarh	CONTINUOUS	HV and Impulse Testing of Extension of GIS at 765kV Aligarh S/S	2019-09-01	08:00	2019-09-03	18:00	58	-
328	POWERGRID	POWERGRID	BUS	765kV BUS-I at ALIGARH	CONTINUOUS	Final connection of Buses for charging with extension at 765kV Aligarh S/S	2019-09-04	08:00	2019-09-06	18:00	58	-
329	POWERGRID	POWERGRID	BUS	765kV Bus-II at Aligarh	CONTINUOUS	Final connection of Buses for charging with extension at 765kV Aligarh S/S	2019-09-07	08:00	2019-09-09	18:00	58	-
330	POWERGRID	POWERGRID	BUS	4OOKV BUS-II AJMER	DAILY	Bus Interlock checking & AMP works	2019-08-23	09:00	2019-08-23	14:00	5	160
331	POWERGRID	POWERGRID	BUS	400KV BUS-I SAHARANPUR	DAILY	For replacement of porcelain Insulator with Polymer Insulator in 400kV Switchyard at Saharanpur	2019-09-02	09:00	2019-09-07	17:00	48	-

332	POWERGRID	POWERGRID	BUS	400KV BUS-II SAHARANPUR	DAILY	For replacement of porcelain Insulator with Polymer Insulator in 400kV Switchyard at Saharanpur	2019-09-09	09:00	2019-09-14	17:00	48	145
333	POWERGRID	POWERGRID	BUS	220 KV BUS-I BAHADURGARH	DAILY	AMP work	2019-09-10	09:00	2019-09-10	18:00	9	152
334	POWERGRID	POWERGRID	BUS	220 KV BUS-II BAHADURGARH	DAILY	AMP work	2019-09-11	09:00	2019-09-11	18:00	9	152
335	POWERGRID	POWERGRID	BUS	220 KV BUS-I AT KOTA	DAILY	AMP work	2019-09-09	09:00	2019-09-09	13:00	4	-
336	POWERGRID	POWERGRID	BUS	220 KV BUS-II AT KOTA	DAILY	AMP work	2019-09-12	09:00	2019-09-12	13:00	4	-
337	POWERGRID	POWERGRID	BUS	400KV Bus-I at Bhadla(PG)	CONTINUOUS	Bus Bar signal testing in SCADA	2019-08-20	09:00	2019-08-20	17:00	8	-
338	POWERGRID	POWERGRID	BUS	400KV Bus-2 at Bhadla(PG)	DAILY	Bus Bar signal testing in SCADA	2019-08-21	09:00	2019-08-21	17:00	8	-
339	POWERGRID	POWERGRID	BUS	220KV Bus-I at Bhadla(PG)	DAILY	Bus Bar signal testing in SCADA	2019-08-23	09:00	2019-08-23	17:00	8	-
340	POWERGRID	POWERGRID	BUS	220KV Bus-2 at Bhadla(PG)	DAILY	Bus Bar signal testing in SCADA	2019-08-24	09:00	2019-08-24	17:00	8	-
341	POWERGRID	POWERGRID	BUS	400 KV BUS-I at Jalandhar	DAILY	For AMP works.	2019-09-27	09:30	2019-09-27	17:30	8	154
342	POWERGRID	POWERGRID	BUS	220kV Bus-I at Gorakhpur Substation	DAILY	For hotspot rectification in 20889 A isolator at Gorakhpur Substation	2019-08-22	09:30	2019-08-22	18:30	9	-
343	POWERGRID	POWERGRID	BUS	220kV Bus-2 at Gorakhpur Substation	DAILY	For hotspot rectification in 20989 B isolator at Gorakhpur Substation	2019-08-23	09:30	2019-08-23	18:30	9	-
344	RRVPN	RRVPN	BUS	765 kV Main Bus-I at 765 kV GSS Anta	DAILY	FOR Halfyearly Maintenance work (Tightning of Nuts & Bolts of Clamp, Fixures & Jumpers).	2019-09-13	09:00	2019-09-13	18:00	9	159
345	RRVPN	RRVPN	BUS	765 kV Main Bus-II at 765 kV GSS Anta	DAILY	FOR Halfyearly Maintenance work (Tightning of Nuts & Bolts of Clamp, Fixures & Jumpers).	2019-09-16	09:00	2019-09-16	18:00	9	159
346	RRVPN	RRVPN	BUS	400 kV Main Bus-I at 765 kV GSS Anta	DAILY	FOR Halfyearly Maintenance work (Tightning of Nuts & Bolts of Clamp, Fixures & Jumpers).	2019-09-23	09:00	2019-09-24	18:00	18	157
347	RRVPN	RRVPN	BUS	400 kV Main Bus-II AT 765 kV GSS Anta	DAILY	FOR Halfyearly Maintenance work (Tightning of Nuts & Bolts of Clamp, Fixures & Jumpers).	2019-09-25	09:00	2019-09-26	18:00	18	157

348	RRVPN	POWERGRID	BUS	400KV BUS-I AJMER	DAILY	HALF YEARLY MAINT.WORK OF 400 KV MAIN BUS BAR-I	2019-09-16	09:00	2019-09-16	18:00	9	157
349	RRVPN	POWERGRID	BUS	4OOKV BUS-II AJMER	DAILY	HALF YEARLY MAINT.WORK OF 400 KV MAIN BUS BAR-II	2019-09-17	09:00	2019-09-17	18:00	9	160
350	RRVPN	RRVPN	BUS	400kV Main Bus - A at 400kV GSS Babai	CONTINUOUS	Equipment erection & Jumpering work by M/s NRSS Trans. Ltd in Dia V&VI for 400 KV D/C Babai-Bhiwani line	2019-09-17	10:00	2019-09-20	17:00	79	159
351	RRVPN	RRVPN	BUS	400kV Main Bus-I at 400KV GSS Bhadla.	DAILY	Quarterly Maintenance work	2019-09-21	17:00	2019-09-21	21:00	4	159
352	RRVPN	RRVPN	BUS	400kV Bus-II at 400KV GSS Bhadla	DAILY	Quarterly Maintenance work	2019-09-25	17:00	2019-09-25	21:00	4	158
353	RRVPN	RRVPN	BUS	400kV Main Bus-I at 400kV GSS Bhilwara	DAILY	Half Yearly maintenance of400 KV MAIN BUS-1 & ASSOCIATED EQUIPMENTS	2019-09-19	09:00	2019-09-19	17:00	8	149
354	RRVPN	RRVPN	BUS	400KV MAIN BUS-B AT 400KV GSS CHITTORGARH	DAILY	FOR MAINTAINCE WORK	2019-09-18	09:00	2019-09-20	17:00	24	153
355	RRVPN	RRVPN	BUS	400kV MAin Bus-I at 400kV GSS Hindaun	DAILY	Quaterly & Half yearly Maintance	2019-09-27	09:00	2019-09-27	17:00	8	160
356	RRVPN	RRVPN	BUS	400KV MAIN BUS-II AT 400KV GSS HINDAUN	DAILY	Quaterly & Half yearly Maintance	2019-09-13	09:00	2019-09-13	15:00	6	160
357	RRVPN	RRVPN	BUS	400kV Bus-B at 400kV GSS Jodhpur	DAILY	3rd Quarterly maintenance work	2019-09-18	09:00	2019-09-19	17:00	16	147
358	RRVPN	RRVPN	BUS	400KV MAIN BUS A RATANGARH	DAILY	Maintenance work of bay equipment	2019-09-11	09:30	2019-09-11	18:00	8.5	158
359	RRVPN	RRVPN	BUS	400kV Main Bus-II at 400kV GSS Babai	CONTINUOUS	Equipment erection & Stringing of Jack Bus by M/s NRSS Trans. Ltd in Dia V&VI for 400 KV D/C Babai-Bhiwani line	2019-09-03	09:00	2019-09-11	17:00	200	-
360	SJVNL	SJVNL	BUS	400 KV GIS Bus Bar - I	DAILY	Minor Leakage as well as Preventive Maintenance only if the plant is under shut down due to high silt or silt flushing. Outages already approved in 161st OCC	2019-08-25	09:30	2019-08-25	17:30	8	161
361	SJVNL	SJVNL	BUS	400 KV GIS BUS COUPLER(RAMPUR)	DAILY	Minor Leakage as well as preventive maintenance only if the plant is under shutdown due to high silt or silt flushing. Outage already approve in 161st OCC but not availed as there was no shutdown.	2019-08-25	09:30	2019-08-25	17:30	8	161
362	SJVNL	SJVNL	BUS	400 KV GIS Bus Bar - II	DAILY	Minor Leakage as well as preventive maintenance only if the plant is under shutdown due to high silt or silt flushing. Outage already approve in 161st OCC but not availed as there was no shutdown.	2019-08-26	09:30	2019-08-26	17:30	8	161

363	SJVNL	SJVNL	BUS	400 KV GIS BUS COUPLER(RAMPUR)	DAILY	Minor Leakage as well as preventive maintenance only if the plant is under shutdown due to high silt or silt flushing. Outage already approve in 161st OCC but not availed as there was no shutdown.	2019-08-26	09:30	2019-08-26	17:30	8	161
364	UPPTCL	UPPTCL	BUS	400 kV Bus1 Greater Noida	CONTINUOUS	For attending of PG isolator of B-Phase Bus-1 of 400 KV NAWADA BAY	2019-09-17	10:00	2019-09-17	18:00	8	159
365	UPPTCL	UPPTCL	BUS	400KV BUS 2 AGRA	DAILY	General Maintenance of 400 kV Main Bus-2	2019-09-02	08:00	2019-09-02	17:00	9	161
366	UPPTCL	UPPTCL	BUS	400KV BUS 1 AGRA	DAILY	General Maintenance of 400 kV Main Bus-1	2019-09-03	08:00	2019-09-03	17:00	9	161
367	UPPTCL	POWERGRID	BUS	400KV Bus-II at Fatehabad	DAILY	Regular Maintenance of BUS-2 and associated Isolator	2019-09-04	07:00	2019-09-05	17:00	20	154
368	UPPTCL	POWERGRID	BUS	400KV BUS-1 FATEHABAD PG (400KV)	DAILY	Regular Maintenance of BUS-1 and associated Isolator	2019-09-06	07:00	2019-09-07	17:00	20	152
369	UPPTCL	UPPTCL	BUS	Bus coupler at Kasara Mau	DAILY	Tightening of complete bay and maintenance work	2019-09-20	09:00	2019-09-20	18:00	9	145
370	UPPTCL	UPPTCL	BUS	400kV MAIN BUS II- Kasara MAU	DAILY	For tightening of Bus coupler main bus -II shutdown is required	2019-09-20	09:00	2019-09-20	18:00	9	-
371	UPPTCL	UPPTCL	BUS	400 KV Main Bus - II at 400 KV S/s Sarnath	CONTINUOUS	Replacement of old & outlived 0.5 accuracy CT by new 0.2 accuracy CT of 400 KV Bus Coupler Bay	2019-09-18	08:00	2019-09-23	18:00	130	156
372	POWERGRID	POWERGRID	FACT	400kv FSC-I Koteshwar-I at Meerut	DAILY	Construction : Testing of 624 KV LA-03 nos in Koteshwer line-1 for FSC-I	2019-09-01	09:00	2019-09-09	18:00	81	-
373	POWERGRID	POWERGRID	FACT	400kv FSC-II Koteshwar-2at Meerut	DAILY	Construction : Testing of 624 KV LA-02 nos in Koteshwer line-2 for FSC-II	2019-09-03	09:00	2019-09-03	18:00	9	-
374	DTL	DTL	ICT	ICT04 BAWANA-CCGT (400KV)(DTL)/315	DAILY	Tan Delta Testing as per OS Manual.	2019-09-24	07:00	2019-09-24	17:00	10	153
375	DTL	DTL	ICT	ICT06 BAWANA-CCGT (400KV)(DTL)/315	DAILY	Tan Delta Testing as per OS Manual.	2019-09-25	07:00	2019-09-25	17:00	10	155
376	DTL	DTL	ICT	ICT03 MUNDKA (400KV)(DTL)/315	DAILY	Testing of Transformer (C& Tan Delta & other tests as per PMS schedule of DTL)	2019-09-06	06:00	2019-09-06	17:30	11.5	153
377	HVPNL	HVPNL	ICT	ICT04/315	DAILY	To attend Hot point on Y phase isolator blade of 418 89A observed during thermo vision scanning on dated 30.07.19, pending observation regarding replacement of DC aluminium control wire with Copper wire.	2019-08-20	10:00	2019-08-20	15:00	5	-

378	HVPNL	HVPNL	ICT	ICT02 DAULTABAD (400KV)(HVPNL)/315	DAILY	Preventive maintenance to prevent probable hot points nodes observed during thermo vision scanning on dated 05.08.19	2019-09-05	10:00	2019-09-05	17:00	7	160
379	NTPC	NTPC	ICT	ICT01 SINGRAULI NTPC (400KV)(NTPC)/100	CONTINUOUS	400 kV ICT-1: for 400kV Breaker Replacement. ICT-1 will be taken on Transfer Bus-1. Main breaker Permit is required. Last day shutdown required of ICT to take main breaker in service.	2019-09-19	08:30	2019-09-23	18:30	106	157
380	NTPC	NTPC	ICT	ICT02 SINGRAULI NTPC (400KV)(NTPC)/100	CONTINUOUS	400 kV ICT-2; for 400kV Breaker Replacement. ICT-2 will be taken on Transfer Bus-2. Main breaker Permit is required. Last day shutdown required of ICT to take main breaker in service	2019-09-24	08:30	2019-09-27	18:30	82	-
381	POWERGRID	POWERGRID	ICT	ICT02 MEERUT (765KV)(POWERGRID)/1500	DAILY	Construction Work :Erection and Testing of equipment of 765 kV ICT-III..S/D due to induction problem.	2019-09-04	09:00	2019-09-04	18:00	9	156
382	POWERGRID	POWERGRID	ICT	ICT02 JHATIKALA(765 KV)(POWERGRID)/1500	DAILY	For RTV coating in ICT-2 in 400KV Interconnection In 400KV ICT-2 Interconnection, Conductor of ICT-3 is runnning over head.	2019-09-05	09:00	2019-09-05	19:00	10	157
383	POWERGRID	POWERGRID	ICT	ICT03 JHATIKALA(765 KV)(POWERGRID)/1500	DAILY	For RTV coating in ICT-2 in 400KV Interconnection In 400KV ICT-2 Interconnection, Conductor of ICT-3 is runnning over head	2019-09-05	09:00	2019-09-05	19:00	10	157
384	POWERGRID	POWERGRID	ICT	ICT01 JHATIKALA(765 KV)(POWERGRID)/1500	DAILY	For RTV coating in ICT-1 in 400KV Interconnection In 400KV ICT-1,Interconnection, Conductor of ICT-2 is runnning over head	2019-09-06	09:00	2019-09-06	19:00	10	157
385	POWERGRID	POWERGRID	ICT	ICT02 JHATIKALA(765 KV)(POWERGRID)/1500	DAILY	For RTV coating in ICT-1 in 400KV Interconnection In 400KV ICT-1,Interconnection, Conductor of ICT-2 is runnning over head	2019-09-06	09:00	2019-09-06	19:00	10	157
386	POWERGRID	POWERGRID	ICT	ICT04 JHATIKALA(765 KV)(POWERGRID)/1500	DAILY	For GE make CSD Tuning and require 04times swicthing of ICT (No load switching)	2019-09-24	09:00	2019-09-24	18:00	9	159
387	POWERGRID	POWERGRID	ICT	765KV 1500MVA ICT-I AJMER/1500	DAILY	NTAMC operation checking work of isolators	2019-08-30	09:30	2019-08-30	10:30	1	160
388	POWERGRID	POWERGRID	ICT	ICT02 BHIWANI-PG (765 KV)(POWERGRID)/1000	DAILY	For Taking B Phase Out of Service and Spare Trafo in service	2019-09-25	10:00	2019-09-25	16:00	6	160
389	POWERGRID	POWERGRID	ICT	765kV, 1500MVA ICT-1 AT BIKANER PG/1500 MVA	DAILY	CSD Fine Tuning/Spare OLTC check with Main Bank	2019-09-12	09:30	2019-09-12	18:30	9	161
390	POWERGRID	POWERGRID	ICT	765kV, 1500MVA ICT-2 AT BIKANER PG/1500 MVA	DAILY	CSD Fine Tuning/Spare OLTC check with Main Bank	2019-09-13	09:00	2019-09-13	18:00	9	161
391	POWERGRID	POWERGRID	ICT	ICT01 LUCKNOW(765 KV)-PG(POWERGRID)/1500	DAILY	For AMP Work at Lucknow S/S	2019-09-14	09:00	2019-09-14	18:00	9	151

392	POWERGRID	POWERGRID	ICT	ICT02 LUCKNOW(765 KV)-PG(POWERGRID)/1500	DAILY	For AMP Work at Lucknow S/S	2019-09-16	09:00	2019-09-16	18:00	9	151
393	POWERGRID	POWERGRID	ICT	ICT-3 at Fatehabad/315MVA	DAILY	For testing and fine tuning of CSD relay installed on ICT-3 at Fatehabad.	2019-09-25	11:30	2019-09-25	14:30	3	159
394	POWERGRID	POWERGRID	ICT	ICT01 SAHRANPUR(POWERGRID)/315	DAILY	For replacement of porcelain Insulator with Polymer Insulator in 400kV Switchyard at Saharanpur	2019-09-09	09:00	2019-09-10	17:00	16	158
395	POWERGRID	POWERGRID	ICT	ICT02 SAHRANPUR(POWERGRID)/315	DAILY	For replacement of porcelain Insulator with Polymer Insulator in 400kV Switchyard at Saharanpur	2019-09-11	09:00	2019-09-12	17:00	16	158
396	POWERGRID	POWERGRID	ICT	ICT01 BHIWADI-PG (400KV)(POWERGRID)/315	CONTINUOUS	All 33kV Bushing Replacement & Degassing work	2019-09-16	08:00	2019-09-21	19:00	131	156
397	POWERGRID	POWERGRID	ICT	ICT02 BHIWADI-PG (400KV)(POWERGRID)/315	CONTINUOUS	All 33kV Bushing Replacement & Degassing work	2019-09-25	08:00	2019-09-30	19:00	131	156
398	POWERGRID	POWERGRID	ICT	ICT01 DEHRADUN (400KV)(POWERGRID)/315	DAILY	AMP WORK	2019-09-05	09:00	2019-09-05	18:00	9	157
399	POWERGRID	POWERGRID	ICT	ICT02 DEHRADUN (400KV)(POWERGRID)/315	DAILY	AMP WORK	2019-09-09	09:00	2019-09-09	18:00	9	157
400	POWERGRID	POWERGRID	ICT	ICT03 MANDOLA (220KV)(POWERGRID)/500	DAILY	For RTV coating in 220KV Gantry insulators and AMP	2019-09-02	08:00	2019-09-02	17:00	9	155
401	POWERGRID	POWERGRID	ICT	ICT02 MANDOLA (220KV)(POWERGRID)/500	DAILY	jumper disconnection of 1289A isolator for isolator replcacement under ADD CAP	2019-09-03	08:00	2019-09-03	17:00	9	159
402	POWERGRID	POWERGRID	ICT	ICT02 MANDOLA (220KV)(POWERGRID)/500	DAILY	For jumpering of bay 412 89A isolator after retrofitmemnt and disconnection of 1189B isolator jumper under ADD CAP.	2019-09-08	14:00	2019-09-08	18:00	4	159
403	POWERGRID	POWERGRID	ICT	ICT02 MANDOLA (220KV)(POWERGRID)/500	DAILY	Jumpering of bay 411 89B isolator after retrofitmemnt under ADD CAP	2019-09-14	14:00	2019-09-14	18:00	4	159
404	POWERGRID	POWERGRID	ICT	ICT01 MANDOLA (220KV)(POWERGRID)/500	DAILY	jumper disconnection of 1589A isolator for isolator replcacement under ADD CAP	2019-09-15	08:00	2019-09-15	18:00	10	159
405	POWERGRID	POWERGRID	ICT	ICT01 MANDOLA (220KV)(POWERGRID)/500	DAILY	Jumpering of bay 415 89A isolator after retrofitmemnt under ADD CAP	2019-09-20	14:00	2019-09-20	18:00	4	159
406	POWERGRID	POWERGRID	ICT	ICT04 MANDOLA (220KV)(POWERGRID)/500	DAILY	For RTV coating in 220KV Gantry insulators and AMP	2019-09-21	08:30	2019-09-21	18:30	10	156
407	POWERGRID	POWERGRID	ICT	ICT01 KOTA (400KV)(POWERGRID)/315	DAILY	AMP WORKS	2019-09-19	09:00	2019-09-19	17:00	8	153

408	POWERGRID	POWERGRID	ICT	ICT01 BALLABGARH-PG (400KV)(POWERGRID)/500	DAILY	S/D required for testing of new retrofitted relays of Transformer protection & AMP works	2019-09-02	09:00	2019-09-02	17:00	8	156
409	POWERGRID	POWERGRID	ICT	ICT02 BALLABGARH-PG (400KV)(POWERGRID)/500	DAILY	S/D required for testing of new retrofitted relays of Transformer protection & AMP works	2019-09-04	09:00	2019-09-04	17:00	8	156
410	POWERGRID	POWERGRID	ICT	ICT02 BHINMAL (400KV)(POWERGRID)/315	DAILY	AMP WORKS	2019-09-02	08:00	2019-09-02	18:00	10	154
411	POWERGRID	POWERGRID	ICT	500MVA ICT-III JALLANDHAR-PG (400KV)(POWERGRID)/500	DAILY	For AMP works.	2019-09-25	09:30	2019-09-25	17:30	8	150
412	POWERGRID	POWERGRID	ICT	ICT04 MOGA (400KV)(POWERGRID)/315	DAILY	For complete testings of bushings which were replaced recently.	2019-09-24	09:30	2019-09-24	17:30	8	157
413	POWERGRID	POWERGRID	ICT	ICT01 LUCKNOW-Kursi Road (400KV) PG(POWERGRID)/315	DAILY	Tertiary cable connection with ICT at 400kV lucknow S/S	2019-09-02	10:00	2019-09-02	15:00	5	159
414	POWERGRID	POWERGRID	ICT	ICT02 LUCKNOW-Kursi Road (400KV) PG(POWERGRID)/500	DAILY	AMP WORK of 500 MVA ICT-2 at 400kV lucknow S/S	2019-09-03	09:00	2019-09-03	17:30	8.5	159
415	POWERGRID	POWERGRID	ICT	ICT02 MAINPURI-PG (400KV)(POWERGRID)/315	DAILY	AMP WORK of ICT-2 at Mainpuri S/S	2019-09-11	09:00	2019-09-11	18:30	9.5	-
416	POWERGRID	POWERGRID	ICT	ICT01 MAINPURI-PG (400KV)(POWERGRID)/315	DAILY	AMP WORK of ICT-1 at Mainpuri S/S	2019-09-09	09:00	2019-09-09	18:30	9.5	152
417	POWERGRID	POWERGRID	ICT	ICT01 GORAKHPUR-PG (400KV)(POWERGRID)/315	DAILY	For oil leakage arrest by application of steel putty at Gorakhpur Substation	2019-08-20	08:00	2019-08-20	18:30	10.5	160
418	POWERGRID	POWERGRID	ICT	ICT02 GORAKHPUR-PG (400KV)(POWERGRID)/315	DAILY	For AMP Works of ICT#2 at Gorakhpur Substation	2019-09-06	08:00	2019-09-06	18:30	10.5	157
419	POWERGRID	POWERGRID	ICT	500MVA ICT-I TUGHLAKABAD/500	CONTINUOUS	For Socket bolt length check in 220kV side (LV) circuit breaker by M/s Hyosung	2019-08-23	09:00	2019-08-25	18:00	57	154
420	POWERGRID	POWERGRID	ICT	500MVA ICT-II TUGHLAKABAD/500	CONTINUOUS	For Socket bolt length check in 220kV side (LV) circuit breaker by M/s Hyosung	2019-08-26	09:00	2019-08-28	18:00	57	154
421	POWERGRID	POWERGRID	ICT	500MVA ICT-III TUGHLAKABAD/500	CONTINUOUS	For Socket bolt length check in 220kV side (LV) circuit breaker by M/s Hyosung	2019-08-29	09:00	2019-08-31	18:00	57	159
422	POWERGRID	POWERGRID	ICT	500MVA ICT-IV TUGHLAKABAD/500	CONTINUOUS	For Socket bolt length check in 220kV side (LV) circuit breaker by M/s Hyosung.	2019-09-01	09:00	2019-09-03	18:00	57	159
423	PTCUL	PTCUL	ICT	ICT01 SRINAGAR_UK (400KV)(PTCUL)/315	DAILY	Form maintenance of T/f and concern Bays.	2019-09-03	10:00	2019-09-03	17:00	7	159

424	PTCUL	PTCUL	ICT	ICT02 SRINAGAR_UK (400KV)(PTCUL)/315	DAILY	For maintenance to T/f and concern Bays.	2019-09-04	10:00	2019-09-04	17:00	7	159
425	PTCUL	PTCUL	ICT	ICT01 RISHIKESH (400KV)(PTCUL)/240	DAILY	For testing & Commissioning of Bus Bar protection panel under PSDF Scheme.	2019-09-11	10:00	2019-09-11	15:00	5	160
426	PTCUL	PTCUL	ICT	ICT02 RISHIKESH (400KV)(PTCUL)/315	DAILY	For testing & Commissioning of Bus Bar protection panel under PSDF Scheme.	2019-09-11	10:00	2019-09-11	15:00	5	160
427	RRVPN	RRVPN	ICT	ICT01 ANTA(765KV)(RRVPN)/1500	DAILY	FOR Halfyearly Maintenance work (Tightning of Nuts & Bolts of Clamp, Fixures & Jumpers).	2019-09-02	09:00	2019-09-03	18:00	18	157
428	RRVPN	RRVPN	ICT	ICT02 ANTA(765KV)(RRVPN)/1500	DAILY	FOR Halfyearly Maintenance work (Tightning of Nuts & Bolts of Clamp, Fixures & Jumpers).	2019-09-04	09:00	2019-09-05	18:00	18	159
429	RRVPN	RRVPN	ICT	ICT03 ANTA(765KV)(RRVPN)/1500	DAILY	FOR Halfyearly Maintenance work (Tightning of Nuts & Bolts of Clamp, Fixures & Jumpers).	2019-09-11	09:00	2019-09-12	18:00	18	158
430	RRVPN	RRVPN	ICT	ICT-III (KANOHAR)/315 MVA	DAILY	HALF YEARLY MAINT.WORK OF 400 KV MAIN BUS BAR-II. (1) As the Tie bay has not commissioned 315 MVA, 400/220 KV Kanohar Make ICT-III will remain 'Off' during	2019-09-17	09:00	2019-09-17	18:00	9	161
431	RRVPN	RRVPN	ICT	400/22kB 315MVA ICT-I at 400kV GSS Babai/315	DAILY	Quarterly Maintenance	2019-09-05	07:00	2019-09-05	13:00	6	159
432	RRVPN	ADANIRJ	ICT	Station Transformer - 1/80	DAILY	1 CVT has drift in Secondary Voltage CVT replacement needed. 2Annual Maintenance of Main and Tie Bay Equipments.	2019-09-24	09:30	2019-09-24	19:00	9.5	159
433	RRVPN	RRVPN	ICT	400/220kV ICT-III at 400kV GSS Babai/315	DAILY	Quarterly Maintenance	2019-09-19	07:00	2019-09-19	13:00	6	158
434	RRVPN	RRVPN	ICT	ICT01 BARMER (400KV)(RRVPN)/315	DAILY	Quarterly Maintenance	2019-09-19	10:00	2019-09-19	18:00	8	159
435	RRVPN	RRVPN	ICT	ICT02 BARMER (400KV)(RRVPN)/315	DAILY	Quarterly Maintenance	2019-09-20	10:00	2019-09-20	18:00	8	159
436	RRVPN	RRVPN	ICT	ICT03 BHADLA (400KV)(RRVPN)/500	DAILY	Quarterly Maintenance work	2019-09-19	17:00	2019-09-19	21:00	4	158
437	RRVPN	RRVPN	ICT	ICT02 HEERAPURA (400KV)(RRVPN)/250	DAILY	3rd Quaterly maintenance of 400 KV side bay Equipments	2019-09-13	10:00	2019-09-13	17:00	7	158
438	RRVPN	RRVPN	ICT	ICT01 HEERAPURA (400KV)(RRVPN)/250	DAILY	3rd Quaterly maintenance of 400 KV side bay Equipments	2019-09-18	10:00	2019-09-18	17:00	7	158
439	RRVPN	RRVPN	ICT	ICT03 HEERAPURA (400KV)(RRVPN)/250	DAILY	3rd Quaterly maintenance of 400 KV side bay Equipments	2019-09-19	10:00	2019-09-19	17:00	7	158

440	RRVPN	RRVPN	ICT	ICT04 HEERAPURA (400KV)(RRVPN)/315	DAILY	3rd Quaterly maintenance of 400 KV side bay Equipments	2019-09-20	10:00	2019-09-20	17:00	7	158
441	RRVPN	RRVPN	ICT	ICT01 HEERAPURA (400KV)(RRVPN)/250	DAILY	3rd Quaterly maintenance of 220 KV side bay Equipments	2019-09-23	10:00	2019-09-23	17:00	7	158
442	RRVPN	RRVPN	ICT	ICT02 HEERAPURA (400KV)(RRVPN)/250	DAILY	3rd Quaterly maintenance of 220 KV side bay Equipments	2019-09-24	10:00	2019-09-24	17:00	7	158
443	RRVPN	RRVPN	ICT	ICT03 HEERAPURA (400KV)(RRVPN)/250	DAILY	3rd Quaterly maintenance of 220 KV side bay Equipments	2019-09-25	10:00	2019-09-25	17:00	7	158
444	RRVPN	RRVPN	ICT	ICT04 HEERAPURA (400KV)(RRVPN)/315	DAILY	3rd Quaterly maintenance of 220 KV side bay Equipments	2019-09-26	10:00	2019-09-26	17:00	7	158
445	RRVPN	RRVPN	ICT	ICT01 JODHPUR (400KV)(RRVPN)/315	DAILY	3rd Quarterly maintenance work SHUTDOWN OF 400KV ILT-Ist WITH 400KV MAIN BUS-B IS TO BE REQUIRED DUE TO FAULTY TIE BREAKER(452T)	2019-09-18	09:00	2019-09-19	17:00	16	159
446	RRVPN	RRVPN	ICT	400/220KV ICT-3 AT 400 KV GSS RAMGARH/315	DAILY	Half yearly Maintenance	2019-09-09	10:00	2019-09-09	17:00	7	160
447	RRVPN	RRVPN	ICT	400/220KV ICT-2 AT 400 KV GSS RAMGARH/315	DAILY	Half yearly Maintenance	2019-09-10	10:00	2019-09-10	17:00	7	151
448	RRVPN	RRVPN	ICT	ICT01 RATANGARH (400KV)(RRVPN)/315	DAILY	Maintenance work of bay equipment	2019-09-04	10:00	2019-09-04	17:00	7	159
449	RRVPN	RRVPN	ICT	ICT03 RATANGARH (400KV)(RRVPN)/315	DAILY	Maintenance work of bay equipment	2019-09-06	09:30	2019-09-06	18:00	8.5	159
450	UPPTCL	UPPTCL	ICT	500 MVA ICT01 LUCKNOW (Sarojini Nagar) 400-UP/500	CONTINUOUS	For NAS Filtration and Variable Frequency Tan Delta Testing by M/S BHEL	2019-09-04	08:00	2019-09-05	17:00	33	159
451	UPPTCL	UPPTCL	ICT	ICT01 BAREILY-UP (400KV)(UPPTCL)/315	CONTINUOUS	Preventive Maintenance & Routine Maintenance	2019-09-03	09:00	2019-09-03	18:00	9	161
452	UPPTCL	UPPTCL	ICT	315 MVA ICT03 BAREILY-UP/315 MVA	CONTINUOUS	For overhauling of transformer including replacement of Gasket	2019-09-05	09:00	2019-10-03	18:00	681	-
453	UPPTCL	UPPTCL	ICT	ICT03 SULTANPUR (400KV)(UPPTCL)/315	DAILY	for routine bay maintenance works	2019-09-06	10:00	2019-09-06	18:00	8	161
454	UPPTCL	UPPTCL	ICT	ICT01 SULTANPUR (400KV)(UPPTCL)/240	DAILY	for routine bay maintenance works	2019-09-03	10:00	2019-09-03	18:00	8	161
455	UPPTCL	UPPTCL	ICT	ICT02 SULTANPUR (400KV)(UPPTCL)/240	DAILY	for routine bay maintenance works	2019-09-25	10:00	2019-09-25	18:00	8	161

456	UPPTCL	UPPTCL	ICT	ICT03 GREATER NOIDA (400KV)(UPPTCL)/500	CONTINUOUS	For Over hauling PG isolator of R-Phase Bus-1 bay of ict	2019-09-09	10:00	2019-09-09	16:00	6	158
457	UPPTCL	UPPTCL	ICT	ICT04 GREATER NOIDA (400KV)(UPPTCL)/500	CONTINUOUS	For attending Y-Phase main bus-1 PG isolator	2019-09-13	10:00	2019-09-13	18:00	8	157
458	UPPTCL	UPPTCL	ICT	ICT03 AGRA-UP (400KV)(UPPTCL)/315	DAILY	General Maintenance of ICT-3,315 MVA	2019-09-04	08:00	2019-09-04	17:00	9	161
459	UPPTCL	UPPTCL	ICT	ICT 01 AGRA-UP (400KV)(UPPTCL)/500	DAILY	General Maintenance of ICT-1,500 MVA	2019-09-05	08:00	2019-09-05	17:00	9	155
460	UPPTCL	UPPTCL	ICT	ICT02 AGRA-UP (400KV)(UPPTCL)/500	DAILY	General Maintenance of ICT-2,500 MVA	2019-09-06	08:00	2019-09-06	17:00	9	155
461	UPPTCL	UPPTCL	ICT	ICT-I MATHURA/315 MVA	DAILY	Routine Testing & Regular Maintenance and Tighening	2019-09-04	08:00	2019-09-05	19:00	22	-
462	UPPTCL	UPPTCL	ICT	ICT-II Agra South/200 MVA	DAILY	Routine Testing & Regular Maintenance and Tightening	2019-09-12	09:00	2019-09-13	15:00	12	161
463	UPPTCL	UPPTCL	ICT	ICT01 MAU (400KV)(UPPTCL)/200	DAILY	Tightening of complete bay and painting of Transformer	2019-09-19	09:00	2019-09-19	18:00	9	159
464	UPPTCL	UPPTCL	ICT	1500 MVA ICT-2 at Hapur S/s/1500 MVA	DAILY	Annual Maintenance of ICT	2019-09-09	10:00	2019-09-10	11:00	2	161
465	UPPTCL	UPPTCL	ICT	ICT GREATER NOIDA(765 KV)(UPPTCL)/1500		Annual Maintenance of ICT	2019-09-03	09:00	2019-09-03	10:00	1	153
466	UPPTCL	UPPTCL	ICT	ICT01 SARNATH (400KV)(UPPTCL)/315	CONTINUOUS	Replacement of old & outlived 400 KV ABCB Circuite Breaker	2019-09-04	08:00	2019-09-16	18:00	298	155
467	UPPTCL	UPPTCL	ICT	ICT ORAI (400KV)(UPPTCL)/315	DAILY	For attending oil leakage from ICT	2019-09-17	10:00	2019-09-17	19:00	9	159
468	UPPTCL	UPPTCL	ICT	ICT I AGRA SOUTH (UPPTCL)/200 MVA	DAILY	Routine Testing & Regular Maintenance and Tightening	2019-09-17	09:00	2019-09-18	15:00	12	158
469	POWERGRID	POWERGRID	REACTOR	Bus Reactor-1 at Aligarh GIS Substation/330.00	DAILY	AMP of Bus Reactor-1 at Aligarh S/S	2019-09-09	09:00	2019-09-09	18:00	9	160
470	POWERGRID	POWERGRID	REACTOR	Bus Reactor-2 at Aligarh GIS Substation/330.00	DAILY	AMP of Bus Reactor-2 at Aligarh S/S	2019-09-10	09:00	2019-09-10	18:00	9	160
471	POWERGRID	POWERGRID	REACTOR	240MVAR S/R 765 KV Chitorgarh-1 at Ajmer/240.00	DAILY	CSD Checking & fine tunning During Shutdown Line will remain in service & line reactor switching to be done after CSD fine tunning work.	2019-08-28	10:30	2019-08-28	13:30	3	156

472	POWERGRID	POWERGRID	REACTOR	330MVAR Kanpur LR at Aligarh GIS Substation/330.00	DAILY	AMP of Kanpur LR at Aligarh S/S.	2019-09-06	09:00	2019-09-06	18:00	9	160
473	POWERGRID	POWERGRID	REACTOR	Orai-1 LR at Aligarh GIS Substation/240.00	DAILY	AMP of Orai-1 LR at Aligarh S/S	2019-09-02	09:00	2019-09-02	18:00	9	160
474	POWERGRID	POWERGRID	REACTOR	Orai-2 LR at Aligarh GIS Substation/240.00	DAILY	AMP of Orai-2 LR at Aligarh S/S	2019-09-03	09:00	2019-09-03	18:00	9	160
475	POWERGRID	POWERGRID	REACTOR	240MVAR S/R 765 KV Chitorgarh-2 at Ajmer/240.00	DAILY	CSD Checking & fine tunning During Shutdown Line will remain in service & line reactor switching to be done after CSD fine tunning work	2019-08-29	10:30	2019-08-29	13:30	3	156
476	POWERGRID	POWERGRID	REACTOR	240MVAR B/Reactor AJMER-765/240.00	DAILY	Spare unit swapping work Spare unit swapping work & NTAMC operation checking work	2019-08-21	09:30	2019-08-21	13:30	4	160
477	POWERGRID	POWERGRID	REACTOR	REACTOR(S) MEERUT (765KV)/240.00	DAILY	Construction Work :Erection and Testing of equipment of Meerut-Koteshwar Line-1 Reactor	2019-09-10	09:00	2019-09-10	18:00	9	158
478	POWERGRID	POWERGRID	REACTOR	REACTORII VINDHYACHAL (400KV)/93.00	DAILY	for AMP WORK of reactor at Vindhyachal S/S	2019-09-16	09:00	2019-09-16	18:00	9	-
479	POWERGRID	POWERGRID	REACTOR	RECATOR III VINDHYACHAL (400KV)/125.00	DAILY	for AMP WORK of reactor-iii at Vindhyachal S/S	2019-09-19	09:00	2019-09-19	18:00	9	-
480	POWERGRID	POWERGRID	REACTOR	REACTOR IV VINDHYACHAL (400KV)/125.00	DAILY	for AMP WORK of reactor-IV at Vindhyachal S/S	2019-09-23	09:00	2019-09-23	18:00	9	-
481	POWERGRID	POWERGRID	REACTOR	REACTOR I VINDHYACHAL (400KV)/93.00	DAILY	for AMP WORK of reactor-I at Vindhyachal S/S	2019-09-26	09:00	2019-09-26	18:00	9	-
482	POWERGRID	POWERGRID	REACTOR	REACTOR-I BHIWANI-PG 765KV/240.00	DAILY	For AMP Work	2019-09-02	09:00	2019-09-02	18:00	9	160
483	POWERGRID	POWERGRID	REACTOR	REACTOR-II BHIWANI-PG (765 KV)/240.00	DAILY	For AMP Work	2019-09-03	09:00	2019-09-03	18:00	9	160
484	POWERGRID	POWERGRID	REACTOR	765KV, 330MVAR BUS REACTOR AT BIKANER/330.00	DAILY	CSD Fine Tuning	2019-09-14	09:00	2019-09-14	18:00	9	161
485	POWERGRID	POWERGRID	REACTOR	765KV 330MVAR L/R AJMER-1 LINE AT BIKANER/330.00	DAILY	CSD Fine Tuning	2019-09-15	09:00	2019-09-16	18:00	18	161
486	POWERGRID	POWERGRID	REACTOR	765KV 330MVAR L/R AJMER-2 LINE AT BIKANER/330.00	DAILY	For CSD Fine Tuning	2019-09-16	09:00	2019-09-16	18:00	9	161
487	POWERGRID	POWERGRID	REACTOR	400kv 125 MVAR B/R AT BIKANER/125.00	DAILY	CSD Fine Tuning	2019-09-17	09:00	2019-09-17	18:00	9	161

488	POWERGRID	POWERGRID	REACTOR	400KV 125MVAR B/R AJMER/125.00	DAILY	AMP works & NTAMC operation checking work	2019-08-22	09:00	2019-08-22	18:00	9	160
489	POWERGRID	POWERGRID	REACTOR	REACTOR-I SAHRANPUR/50.00	DAILY	For replacement of porcelain Insulator with Polymer Insulator in 400kV Switchyard at Saharanpur	2019-09-11	09:00	2019-09-12	17:00	16	158
490	POWERGRID	POWERGRID	REACTOR	REACTOR II SAHRANPUR/50.00	DAILY	For replacement of porcelain Insulator with Polymer Insulator in 400kV Switchyard at Saharanpur	2019-09-13	09:00	2019-09-14	17:00	16	158
491	POWERGRID	POWERGRID	REACTOR	REACTOR DEHRADUN (400KV)/80.00	DAILY	AMP WORKS	2019-09-12	09:00	2019-09-12	18:00	9	149
492	POWERGRID	POWERGRID	REACTOR	80MVAR B/R -I KOTA/80.00	DAILY	AMP WORKS	2019-09-16	09:00	2019-09-16	17:00	8	150
493	POWERGRID	POWERGRID	REACTOR	REACTOR II KOTA (400KV)/80.00	DAILY	AMP WORKS	2019-09-23	09:00	2019-09-23	17:00	8	150
494	POWERGRID	POWERGRID	REACTOR	50MVAR Koteshwar -I Sw L/R at meerut/50.00	DAILY	AMP Work	2019-09-25	09:00	2019-09-25	18:00	9	160
495	POWERGRID	POWERGRID	REACTOR	50MVAR Koteshwar -II Sw L/R at meerut/50.00	DAILY	AMP Work	2019-09-26	09:00	2019-09-26	18:00	9	160
496	POWERGRID	POWERGRID	REACTOR	240Mvar Bareilly Line Reactor at Lucknow/240.00	DAILY	For AMP work o Reactor at Lucknow S/S.	2019-09-10	09:00	2019-09-10	18:00	9	-
497	POWERGRID	POWERGRID	REACTOR	240Mvar Ballia Line Reactor at LUCKNOW/240.00	DAILY	For AMP work of Reactor at Lucknow S/S	2019-09-09	09:00	2019-09-09	18:00	9	-
498	POWERGRID	POWERGRID	REACTOR	REACTOR JALLANDHAR-PG (400KV)/125.00	DAILY	For AMP works.	2019-09-10	09:30	2019-09-10	17:30	8	-
499	POWERGRID	POWERGRID	REACTOR	50MVAR Line Reactor on Sohawal-Ballia-2 at Sohawal/50.00	CONTINUOUS	Construction activity: For construction of CB Foundation to make LR to Switchable LR and Commissioning of CB etc towards this at Sohawal Substation. S/D is upto 25.10.2019	2019-09-26	09:30	2019-10-01	18:30	129	-
500	POWERGRID	POWERGRID	REACTOR	400kV 125MVAR Bus Reactor at 765/400kV lucknow S/S/125.00	DAILY	For AMP Work of B/R at 765/400kV Lucknow S/S	2019-09-18	09:30	2019-09-18	18:30	9	-
501	PTCUL	PTCUL	REACTOR	REACTOR RISHIKESH (400KV)/50.00	DAILY	For testing & Commissioning of Bus Bar protection panel under PSDF Scheme.	2019-09-11	10:00	2019-09-11	15:00	5	160
502	RRVPN	RRVPN	REACTOR	Reactor Bank 2 ANTA(765KV)/240.00	DAILY	FOR Halfyearly Maintenance work (Tightning of Nuts & Bolts of Clamp, Fixures & Jumpers).	2019-09-06	09:00	2019-09-06	18:00	9	155
503	RRVPN	RRVPN	REACTOR	Reactor Bank 1 ANTA(765KV)/240.00	DAILY	FOR Halfyearly Maintenance work (Tightning of Nuts & Bolts of Clamp, Fixures & Jumpers).	2019-09-27	09:00	2019-09-27	18:00	9	161

504	RRVPN	ADANIRJ	REACTOR	Bus Rector -1 KAWAI SCTPS (400KV)/63.00	DAILY	Annual Maintenance of Bus Reactor 1 & connected isolators & LA	2019-09-05	09:30	2019-09-05	19:30	10	-
505	RRVPN	RRVPN	REACTOR	80MVAR Bus Reactor at 400kV GSS Babai/80.00	DAILY	Quarterly Maintenance	2019-09-12	07:00	2019-09-12	11:00	4	159
506	RRVPN	RRVPN	REACTOR	Series Reactor 1 BHADLA (400KV)/50.00	DAILY	Quarterly Maintenance	2019-09-11	17:00	2019-09-11	21:00	4	157
507	RRVPN	RRVPN	REACTOR	Series Reactor 2 BHADLA (400KV)/50.00	DAILY	Quarterly Maintenance	2019-09-13	17:00	2019-09-13	21:00	4	157
508	RRVPN	RRVPN	REACTOR	SHUNT REACTOR BHILWARA (400KV)/50.00	DAILY	Half Yearly maintenance of 400 KV BUS REACTOR BAY(4452A) & ASSOCIATED EQUIPMENTS	2019-09-23	09:00	2019-09-23	17:00	8	161
509	RRVPN	RRVPN	REACTOR	400kV 80 MVAR Reactor at 400kV GSS Chittorgarh/80.00	DAILY	FOR MAINTAINCE WORK	2019-09-05	09:30	2019-09-05	16:30	7	158
510	RRVPN	RRVPN	REACTOR	Shunt Reactor (line reactor for Akal Bay)/50.00	DAILY	3rd Quarterly maintenance work	2019-09-26	09:00	2019-09-26	17:00	8	150
511	RRVPN	RRVPN	REACTOR	50MVAR Reactor Kota line/50.00	DAILY	II-QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	2019-09-19	10:00	2019-09-19	17:00	7	160
512	RRVPN	RRVPN	REACTOR	REACTOR MERTA (400KV)/50.00	DAILY	II-QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	2019-09-20	09:00	2019-09-20	17:00	8	158
513	RRVPN	RRVPN	REACTOR	400KV 50MVAR LINER REACTOR FOR 400KV AKAL-RAMGARH-I AT RAMGARH/50.00	DAILY	Half yearly Maintenance	2019-09-05	10:00	2019-09-05	17:00	7	160
514	RRVPN	RRVPN	REACTOR	400KV 50MVAR LINER REACTOR FOR 400KV AKAL-RAMGARH-II AT RAMGARH/50.00	DAILY	Half yearly Maintenance	2019-09-06	10:00	2019-09-06	17:00	7	160
515	RRVPN	RRVPN	REACTOR	400 kV 125 MVAR Bus Reactor at 400kV GSS Ramgarh/125.00	DAILY	Half yearly Maintenance	2019-09-07	10:00	2019-09-07	17:00	7	160
516	RRVPN	RRVPN	REACTOR	Shunt Reactor RATANGARH (400KV)/125.00	DAILY	Maintenance work of bay equipment	2019-09-18	09:30	2019-09-18	13:30	4	-
517	RRVPN	RRVPN	REACTOR	50MVAR 400kV Bus Raector at 400kV GSS Kankani/50.00	DAILY	Quarterly Maintenance Work	2019-09-06	09:00	2019-09-06	18:00	9	-
518	SJVNL	SJVNL	REACTOR	REACTOR RAMPUR HEP (400KV)/80.00	DAILY	Minor Leakage as well as preventive maintenance only if the plant is under shutdown due to high silt or silt flushing. Outage already approve in 161st OCC but not availed as there was no shutdown.	2019-08-26	09:30	2019-08-26	17:30	8	161
519	UPPTCL	UPPTCL	REACTOR	3X63 MVAR Bus Reactor Unnao(765 kV)/63.00	DAILY	For routine protection and testing	2019-09-19	08:00	2019-09-19	08:18	0.3	-

520	UPPTCL	UPPTCL	REACTOR	765kV Bus reactor at Fatehabad S/S/80.00	DAILY	For normalised Bus Reactor unit. (Presently Spare Unit is charged in place of R-Ph)	2019-09-11	08:00	2019-09-11	12:00	4	159
521	UPPTCL	UPPTCL	REACTOR	400 kV Bus Reactor at 765 kV Fatehabad (UPPTCL)/80.00	DAILY	Annual Maintenance of 125MVAr Bus Reactor Unit and asscociated 412 Bay	2019-09-09	08:00	2019-09-10	18:00	20	159
522	UPPTCL	UPPTCL	REACTOR	63 MVAR Bus Reactor Banda(400kV)/63.00	DAILY	For routine testing of 63 MVAR Bus Reactor	2019-09-12	11:00	2019-09-12	15:00	4	-
523	POWERGRID	POWERGRID	SVC	400 MVAR STATCOM Nalagarh	CONTINUOUS	For post charging comprehensive maintenance work.	2019-08-26	09:30	2019-08-27	17:30	32	-